









## Digest 173 Sections Revised through 2nd Quarter '06



Below are links to Digest product line sections revised or updated October '03 through June '06. Included are changes related to new products, revised pricing, technical corrections, and more. These sections contain the most accurate, up-to-date information available. They may also reflect new features, expanded product lines, and globalization efforts.

[Section 1: Load Centers](#) – [Section 2: Metering](#) – [Section 3: Safety Switches](#) –  
[Section 4: Power Monitoring & Control](#) – [Section 5: Surge Protective Devices](#) –  
[Section 6: Circuit Breakers](#) – [Section 7: Operating Mechanisms and Disconnect Switches](#) –  
[Section 8: Panelboards](#) – [Section 9: Switchboards and Switchgear](#) – [Section 10: Busway](#) –  
[Section 11: Wire Management](#) – [Section 12: Transformers](#) – [Section 13: Medical Products](#) –  
[Section 14: NEMA Contactors and Starters](#) – [Section 15: Motor Control Centers](#) –  
[Section 16: IEC Style Contactors and Starters](#) – [Section 17: Push Buttons & Operator Interface](#) –  
[Section 19: Limit Switches](#) – [Section 20: Pressure, Vacuum, Temperature and Float Switches](#) –  
[Section 21: Relays & Timers](#) – [Section 22: Terminal Blocks](#) – [Section 24: AC Drives & Soft Starts](#)  
[Section 25: Automation Products](#) – [index](#)

[Links: Featured Products](#) — [CAD Drawings](#) — [Alphanumeric Price Search](#) — [Competitive Cross Reference](#) — [Technical Library](#) — [Product FAQs](#) —  
[Online Literature Fulfillment \(customer version\)](#) — [Back to Online Catalog](#)

Section 1 - Load Centers		Change Date
 <a href="#">Page 1-1 Table of Contents</a>	"and Riser" added to table of contents entry for QO and Homeline Value Pack and Riser Load Centers.	7/2004
 <a href="#">Page 1-4 QO Load Centers</a>	<ul style="list-style-type: none"> <li>▪ On the bottom table (Main Circuit Breaker), <b>QOM2</b> added below Feed Thru to clarify the main breaker type.</li> <li>▪ On the bottom table (Main Circuit Breaker), QOM2 changed to QOM1/QOM2</li> <li>▪ Added ☆ footnote: QO1612M125FTRB provided with QOM1 frame main circuit breaker. QO1816M150FTRB and QO1816M200FTRB provided with QOM2 frame main circuit breaker.</li> </ul>	<ul style="list-style-type: none"> <li>• 9/2004</li> <li>• 12/2005</li> <li>• 12/2005</li> </ul>
 <a href="#">Page 1-5 Three Phase Load Centers</a>	Added ◇ footnote: Certified to IEC 60439-1 for use on 415Y/240 Vac 3 phase 4 wire, 3,000 SCCR when QODX... branch breakers are used and 10,000 SCCR when QO...VS branch breakers are used. CE marked	6/2005
 <a href="#">Page 1-6 QO Load Centers</a>	<ul style="list-style-type: none"> <li>▪ Riser table removed (info on page 1-7)</li> <li>▪ Adding of new QO/Kohler generator panels to this page.</li> </ul>	<ul style="list-style-type: none"> <li>▪ 7/2004</li> <li>▪ 3/2006</li> </ul>
  <a href="#">Page 1-7 QO &amp; Homeline Load Centers</a>	<ul style="list-style-type: none"> <li>▪ Added new Value Pak Load Centers</li> <li>▪ Riser table corrected to read "1 Phase—3 Wire 120/240 Vac—Offset Interior Wide Gutter—30 A Maximum Branch Circuit Breaker on left side of interior"</li> <li>▪ Footnote symbols for Riser table revised for clarity</li> <li>▪ In Riser table, "Fixed" Mains changed to "Convertible" Mains</li> </ul>	<ul style="list-style-type: none"> <li>▪ 7/2004</li> <li>▪ 3/2005</li> <li>▪ 12/2005</li> <li>▪ 12/2005</li> </ul>
  <a href="#">Page 1-8 QO Load Centers Accessories</a>	<ul style="list-style-type: none"> <li>▪ Description of generator circuit breaker interlock kit revised.</li> <li>▪ Added:                             <ul style="list-style-type: none"> <li>▪ "Replacement Cover Directory Label"</li> <li>▪ "Circuit identification Stickers"</li> </ul> </li> <li>▪ Corrected the description on the retaining kits to read: Secures three-pole circuit breaker without accessories to left side of interior when used as a back-fed main. For 3Ø Load Centers.</li> </ul>	<ul style="list-style-type: none"> <li>▪ 7/2004</li> <li>▪ 3/2005</li> <li>▪ 6/2005</li> </ul>

[Back to top](#)

[Back to top](#)

Section 1 - Load Centers (cont.)		Change Date
  <b>Page 1-9 QO &amp; Homeline Load Centers Accessories. Voltage Testers</b>	<ul style="list-style-type: none"> <li>▪ Description of generator circuit breaker interlock kit revised.</li> <li>▪ Moved location of Voltage Testers table.</li> <li>▪ Added:                             <ul style="list-style-type: none"> <li>▪ "Replacement Cover Directory Label"</li> <li>▪ "Circuit identification Stickers"</li> </ul> </li> <li>▪ Page header corrected , changing "Accessories" to "Voltage Testers"</li> </ul>	<ul style="list-style-type: none"> <li>▪ 7/2004</li> <li>▪ 7/2004</li> <li>▪ 3/2005</li> <li>▪ 6/2005</li> </ul>
 <b>Page 1-10 Homeline Load Centers. Indoor—Single Phase, Main Lug, Main Circuit Breaker</b>	<ul style="list-style-type: none"> <li>▪ Max number of tandem circuit breakers changed in the Convertible Mains — Factory-installed Main Lugs, QOM2 Main Frame Size</li> <li>▪ Corrected ▼ footnote to "70 A maximum branch circuit breaker, 100 A maximum back feed main circuit breaker."</li> </ul>	<ul style="list-style-type: none"> <li>▪ 7/2004</li> <li>▪ 3/2005</li> </ul>
 <b>Page 1-11 Homeline Load Centers Rainproof Single Phase, Main Lug, Main Circuit Breaker</b>	<ul style="list-style-type: none"> <li>▪ Added Convertible Mains Factory-installed Main Circuit Breaker QOM2 Main Frame Size</li> <li>▪ Added Δ footnote "70 A maximum branch circuit breaker, 100 A maximum back feed main circuit breaker."</li> <li>▪ In Main Circuit Breaker table, Universal Main -- or Main Lugs added</li> </ul>	<ul style="list-style-type: none"> <li>▪ 7/2004</li> <li>▪ 3/2005</li> <li>▪ 12/2005</li> </ul>
 <b>Page 1-12 QO and HOMELINE Load Centers Indoor Dimensions, Knockouts</b>	<ul style="list-style-type: none"> <li>▪ Revised Knockouts sizes in large ampere boxes and added new wide gutter box dimensions</li> <li>▪ Added QO-AFI and AFI to two footnotes.</li> </ul>	<ul style="list-style-type: none"> <li>▪ 7/2004</li> <li>▪ 6/2006</li> </ul>
 <b>Page 1-13 QO and HOMELINE Load Centers Bolt-On Hubs</b>	<p>Corrected text to reflect: "RB" devices will accept 3/4" through 2-1/2" bolt-on hubs without the use of reducers.</p>	<ul style="list-style-type: none"> <li>7/2004</li> </ul>
  <b>Page 1-14 Combination Service Entrance Devices — Rainproof Single Phase, Meter-Mains</b>	<ul style="list-style-type: none"> <li>▪ Added new 300 and 400 amp. CSED Devices.</li> <li>▪ Corrected breaker catalog numbers and footnotes.</li> <li>▪ Added ● footnote regarding overhead surface applications.</li> <li>▪ Corrected Ampere Rating (Max.) for QOH from 200 to 125</li> <li>▪ Corrected table layout for 400 amp. Ring Type</li> </ul>	<ul style="list-style-type: none"> <li>▪ 7/2004</li> <li>▪ 7/2004</li> <li>▪ 7/2004</li> <li>▪ 3/2005</li> <li>▪ 6/2005</li> </ul>
 <b>Page 1-14 thru 1-16 Load Centers</b>	<p>Adding new devices, change to All-In-Ones specifications, change in chart footnotes for ring and ringless types, change in accessories descriptions for anti-inversion kit, ringless type and lug kit.</p>	<ul style="list-style-type: none"> <li>3/2006</li> </ul>
  <b>Page 1-15 Combination Service Entrance Devices — Rainproof Single Phase, All-In-Ones</b>	<ul style="list-style-type: none"> <li>▪ Added new 300 and 400 amp. CSED Devices.</li> <li>▪ Corrected breaker catalog numbers and footnotes.</li> <li>▪ Added footnote regarding overhead surface applications.</li> <li>▪ Added new product -- SU3040D300CN -- Surface Mount, convertible to Semi flush with FK400 flange kit</li> </ul>	<ul style="list-style-type: none"> <li>▪ 7/2004</li> <li>▪ 7/2004</li> <li>▪ 7/2004</li> <li>▪ 3/2005</li> </ul>









[Back to top](#)

[Back to top](#)

Section 1 - Load Centers (cont.)		Change Date
  <b>Page 1-16 Combination Service Entrance Devices — Circuit Breakers, Accessories, Hubs</b>	Revised ★ footnote <ul style="list-style-type: none"> <li>▪ Revised description for Ringless Type Utility Cover</li> <li>▪ Added new products -- 2920910001 and MMRLK</li> <li>▪ Corrected Catalog number "MMRLK" to "MMLRK"</li> <li>▪ Removed "Meter socket Jaw" from Anti-Inversion Kit</li> </ul>	<ul style="list-style-type: none"> <li>▪ 7/2004</li> <li>▪ 7/2004</li> <li>▪ 3/2005</li> <li>▪ 6/2005</li> <li>▪ 6/2005</li> </ul>
  <b>Page 1-17 Combination Service Entrance Devices — Dimensions</b>	<ul style="list-style-type: none"> <li>▪ Added new 300 and 400 amp. CSED Devices.</li> </ul> Added: ♦ <b>Note 3:</b> Unit supplied with semi-flush top endwall factory installed and semi-flush flanges factory included. <ul style="list-style-type: none"> <li>▪ Added CU12L400FN, CU12L400FB, CU816D400FN, CU816D400FB, QU816D400CK, QU12L400FL, QU816D400FL</li> <li>▪ Added SU3040D300FB, SU3040D400FB, SU3040D400FN, RU3040D400FL, RU3040D400FK</li> </ul>	<ul style="list-style-type: none"> <li>▪ 7/2004</li> <li>▪ 12/2005</li> <li>▪ 12/2005</li> <li>▪ 12/2005</li> </ul>
  <b>Page 1-18 Enclosed Molded Case Switches, Enclosed GFCI Circuit Breakers, Circuit Breaker Enclosures</b>	<ul style="list-style-type: none"> <li>▪ Corrected footnotes and added QO--AFI circuit breakers to description</li> <li>▪ On the last line of the copy description under CB Enclosures in the upper right of the page, the equipment ground bar should be a "PKOGTA2" not a PKOGTA2</li> <li>▪ Price change in chart for rainproof enclosed molded case switches</li> </ul>	<ul style="list-style-type: none"> <li>▪ 7/2004</li> <li>▪ 1/2005</li> <li>▪ 3/2006</li> </ul>
 <b>Page 1-19 Air Conditioning Disconnects Voltage Testers</b>	<ul style="list-style-type: none"> <li>▪ Added 2 Wire—240 Vac Maximum—with 20 A GFI receptacle &amp; 2 Wire—240 Vac Maximum with 20 A duplex receptacle to the not fusible table</li> <li>▪ Corrected dimensions for Height and Width, which were reversed</li> <li>▪ Removed "Voltage Tester" from page heading. Product on Page 1-9</li> </ul>	<ul style="list-style-type: none"> <li>▪ 9/2004</li> <li>▪ 9/2004</li> <li>▪ 6/2005</li> </ul>
 <b>Page 1-22 Multi-Link Structured Wiring System</b>	<ul style="list-style-type: none"> <li>▪ Corrected Pricing for Wall Plates</li> <li>▪ Catalog number SDM5DE100 (Ethernet switch, 10/100 Base-T certified, 8 - RJ-45 ports, uplink port, grid mount, 120 Vac power supply included) added</li> </ul>	<ul style="list-style-type: none"> <li>▪ 3/2005</li> <li>▪ 12/2005</li> </ul>
  <b>Page 1-21 Multi-Link Structured Wiring System</b>	<ul style="list-style-type: none"> <li>▪ Removed Pre-wiring with standard Cat-5 and RG-6 cables paragraph</li> <li>▪ Corrected pricing for SDM18CW, SDM36CW</li> </ul>	7/2004
  <b>Page 1-22 Multi-Link Structured Wiring System</b>	<ul style="list-style-type: none"> <li>▪ Removed router hub.</li> <li>▪ Added new wall plates</li> </ul>	7/2004










[Back to top](#)

[Back to top](#)

Section 2 - Metering		Change Date
  <b>Page 2-3</b> <ul style="list-style-type: none"> <li>▪ <b>Horizontal Ganged Meter Sockets</b></li> <li>▪ <b>Surface Mount, Ring Type, Meter Main with Test Block Bypass</b></li> </ul>	<ul style="list-style-type: none"> <li>▪ Added new product, catalog number UT3R1122B</li> <li>▪ Corrected table info for EMT1225CB and EMT3225CB. Requires use of EZM125QOA adapter (order separately), when using QO (40A-125A, 2-Pole) 10kA max. SCCR, QO-VH (40A-60A, 2-Pole) 22kA max. SCCR, or QOH (40A-60A, 2-Pole) 42kA max. SCCR. Refer to page 2-15 for pricing</li> <li>▪ ☆ footnote deleted</li> <li>▪ Meter Sockets - Removed 29008G</li> </ul>	<ul style="list-style-type: none"> <li>▪ 7/2004</li> <li>▪ 6/2005</li> <li>▪ 12/2005</li> <li>▪ 6/2006</li> </ul>
 <b>Page 2-4 thru 2-6 Metering Equipment</b>	Addition of wording to 19R & 20R meter socket drawing and the removal of 4100CT9801 as a reference catalog.	3/2006
 <b>Page 2-4</b> <ul style="list-style-type: none"> <li>▪ <b>Individual Metering</b></li> <li>▪ <b>Horizontal Ganged Meter Sockets</b></li> </ul>	<ul style="list-style-type: none"> <li>▪ Caption in lower left corner corrected to read EMT1225CB and EMT3225CB, instead of EMT1200CB and EMT3200CB.</li> <li>▪ Added new enclosure Dimensions</li> </ul>	7/2004
 <b>Page 2-5 MP Meter-Pak Meter Centers</b>	In the Ringless Type table, for 225 amp, 2-pole, changed 300 to 350	12/2005
 <b>Page 2-6 MP Meter-Pak</b>	<ul style="list-style-type: none"> <li>▪ Corrected catalog numbers in accessories table: MM200MB, MPL43225, MPL53225, MPL64225, MPL32-225, MPL53-225, and MPL64-225</li> <li>▪ In the accessories table, Horn Bypass Kit, added (for MPR and MPH only)</li> <li>▪ Meter Pak - Minor corrections/additions to charts</li> </ul>	<ul style="list-style-type: none"> <li>▪ 7/2004</li> <li>▪ 12/2005</li> <li>▪ 6/2006</li> </ul>
 <b>Page 2-7 MP Meter-Pak Meter Centers Dimensions, Knockouts</b>	Changed "Plate" to plural "Plates."	12/2005
 <b>Page 2-8 EZM Metering</b>	<ul style="list-style-type: none"> <li>▪ Added ▲ footnote to Square D Certified Ratings for Downstream Panelboards table.</li> <li>▪ Corrected Branch Unit information</li> <li>▪ In Main Devices, "1600 A and 2000 A main disconnects and 1600 A terminal box <b>must be center mounted</b>" changed to:                             <ul style="list-style-type: none"> <li>▪ 1600 A main disconnect or terminal box <b>must be center mounted.</b></li> <li>▪ 2000 A main disconnect <b>must be center mounted</b> and requires use of branch units having 1200 A horizontal cross bus.</li> </ul> </li> <li>▪ Square D Certified Ratings for Downstream Panelboards table removed, replaced with: "For Load Center Series Ratings used downstream from Metering Equipment, refer to Data Bulletins #: 4100DB0301 and 2700DB9901."</li> </ul>	<ul style="list-style-type: none"> <li>▪ 7/2004</li> <li>▪ 3/2005</li> <li>▪ 12/2005</li> <li>▪ 12/2005</li> </ul>


[Back to top](#)

[Back to top](#)









Section 2 - Metering (cont.)		Change Date
  <b>Page 2-8 thru 2-16</b> <b>Metering Equipment</b>	<p>Multiple changes and additions to descriptions and charts on all of these pages plus the removal of 4100CT9801 as a reference catalog.</p>	<p>3/2006</p>
 <b>Page 2-9</b> <b>EZM Metering</b>	<ul style="list-style-type: none"> <li>▪ Corrected amperage information in EZ METER-PAK—Main Lugs Terminal Box Applications Protected By Remote Main table.</li> <li>▪ Deleted 18,000 Amp EZ Meter Pak</li> <li>▪ Added 2000 A EZM Main Device with Type RJ (2000 A) Circuit Breaker</li> <li>▪ Corrected amperage information in EZ METER-PAK—Main Lugs Terminal Box Applications Protected By Remote Main table, 100,000 -- DJM (400 A, 2 or 3-Pole, 160–400 A)</li> <li>▪ In EZ Meter-Pak—Main Circuit Breaker Applications table, added: QD (225 A, 3-Pole, 70–225 A)</li> </ul>	<ul style="list-style-type: none"> <li>▪ 7/2004</li> <li>▪ 3/2005</li> <li>▪ 3/2005</li> <li>▪ 12/2005</li> <li>▪ 12/2005</li> </ul>
 <b>Page 2-10</b> <b>EZM Metering</b>	<ul style="list-style-type: none"> <li>▪ Corrected wire size in Main Lugs Terminal Boxes table</li> <li>▪ Corrections to Main Devices—NEMA 3R Construction information and catalog numbers</li> <li>▪ Corrected <math>\Delta</math> footnote to: Ampere rating of the PA circuit breaker supplied with this main can be changed to a LOWER value in the field by ordering a different set of rating columns, refer to page 6-25 for listing.</li> </ul>	<ul style="list-style-type: none"> <li>▪ 8/2004</li> <li>▪ 3/2005</li> <li>▪ 12/2005</li> </ul>
 <b>Page 2-11</b> <b>EZM Metering</b>	<ul style="list-style-type: none"> <li>▪ Corrected footnotes:                             <ul style="list-style-type: none"> <li>▪ Removed all <math>\blacklozenge</math> footnotes</li> <li>▪ Added <math>\blacktriangledown</math> footnote</li> </ul> </li> <li>▪ Corrected 1<math>\emptyset</math>3W EZ Meter-Pak Meter Centers — UL Listed information</li> </ul>	<ul style="list-style-type: none"> <li>▪ 7/2004</li> <li>▪ 3/2005</li> </ul>
 <b>Page 2-12</b> <b>EZM Metering</b>	<ul style="list-style-type: none"> <li>▪ Corrected wire size</li> <li>▪ <math>\blacklozenge</math> footnote revised</li> <li>▪ Corrected Main Devices—NEMA 3R Construction information</li> <li>▪ Corrected <math>\Delta</math> footnote to: Ampere rating of the PA circuit breaker supplied with this main can be changed to a LOWER value in the field by ordering a different set of rating columns, refer to page 6-25 for listing.</li> <li>▪ EZM – Minor corrections/additions to charts.</li> </ul>	<ul style="list-style-type: none"> <li>▪ 8/2004</li> <li>▪ 8/2004</li> <li>▪ 3/2005</li> <li>▪ 12/2005</li> <li>▪ 6/2006</li> </ul>
 <b>Page 2-13</b> <b>EZM Metering</b>	<ul style="list-style-type: none"> <li>▪ Added <math>\blackstar</math> footnote</li> <li>▪ Removed <math>\blacktriangledown</math> footnotes.</li> <li>▪ Corrected 3<math>\emptyset</math>4W EZ Meter-Pak Meter Centers — UL Listed information</li> </ul>	<ul style="list-style-type: none"> <li>▪ 7/2004</li> <li>▪ 7/2004</li> <li>▪ 3/2005</li> </ul>
 <b>Page 2-14</b> <b>EZM Metering</b>	<ul style="list-style-type: none"> <li>▪ Corrected busway information -- EZ METER-PAK metering equipment is available for use in high rise applications for connection to 800 A–5000 A I-Line or I-Line II plug-in busway installed as a vertical riser.</li> <li>▪ Corrected 3<math>\emptyset</math>4W EZ Meter-Pak Meter Centers — UL Listed information</li> </ul>	<ul style="list-style-type: none"> <li>▪ 7/2004</li> <li>▪ 3/2005</li> </ul>
 <b>Page 2-15</b> <b>EZM Metering</b>	<ul style="list-style-type: none"> <li>▪ Corrected description on QO adapter</li> <li>▪ Corrected information in Accessory table and 225 A Max. EZM Branch Unit Tenant Circuit Breakers</li> <li>▪ Catalog number QPFP corrected to QOFF</li> <li>▪ EZM – Minor corrections/additions to charts and notes</li> </ul>	<ul style="list-style-type: none"> <li>▪ 8/2004</li> <li>▪ 3/2005</li> <li>▪ 12/2005</li> <li>▪ 6/2006</li> </ul>

[Back to top](#)

[Back to top](#)









Section 2 - Metering (cont.)		Change Date
 Page 2-16 EZM Metering	<ul style="list-style-type: none"> <li>▪ Correction to depth on several items in Branch Devices dimension table</li> <li>▪ Corrected catalog number info in Main and Branch Devices table</li> <li>▪ Corrected table information for EZM1800TB &amp; EZM3800TB                             <ul style="list-style-type: none"> <li>▪ Corrected catalog number "EZM1800TB [CU]" to "EZM1800TBCU"</li> <li>▪ Corrected catalog number "EZM3800TB [CU]" to "EZM3800TBCU"</li> </ul> </li> <li>▪ EZ Meter – Pak – Corrections to some tap box dimensions.</li> </ul>	<ul style="list-style-type: none"> <li>▪ 7/2004</li> <li>▪ 3/2005</li> <li>▪ 6/2005</li> <li>▪ 6/2006</li> </ul>

[Back to top](#)

Section 3 - Safety Switches		Change Date
 Page 3-1 Heavy Duty Safety Switches	New Type 316 Enclosure added to "Special Application Enclosures"	9/2004
 Page 3-2 General Duty Safety Switches	<ul style="list-style-type: none"> <li>▪ Added the following note: " 400A requires moving load base"</li> <li>▪ Corrected wiring diagrams. Added "N" in box</li> </ul>	<ul style="list-style-type: none"> <li>▪ 7/2004</li> <li>▪ 6/2005</li> </ul>
 Page 3-3 General Duty Safety Switches	Corrected lug information on field installable lug kits.	6/2005
 Page 3-4 Heavy Duty Safety Switches	<ul style="list-style-type: none"> <li>▪ Note in NEMA Type 4, 4X, 5 header modified to read: 304 Stainless Steel (for 316 stainless see page 3-7) Dust tight, Watertight, Corrosion Resistant (watertight Hubs page 3-9)</li> <li>▪ Corrected wiring diagrams. Added "N" in box</li> </ul>	<ul style="list-style-type: none"> <li>▪ 9/2004</li> <li>▪ 6/2005</li> </ul>
 Page 3-4 thru 3-8, 3-11 and 3-18 Safety Switches	Removal of reference to catalog 3100CT9801	3/2006
 Page 3-7, 3-8, 3-11, and 3-13 Safety Switches	Cast Aluminum Enclosed Switches – Delete product listing.	6/2006
  Page 3-5 Heavy Duty Safety Switches	<ul style="list-style-type: none"> <li>▪ Added items to 2 Wire (2 Blades and Fuseholders)—600 Vac, 600 Vdc Horsepower rating table</li> <li>▪ Note in NEMA Type 4, 4X, 5 header modified to read: 304 Stainless Steel (for 316 stainless see page 3-7) Dusttight, Watertight, Corrosion Resistant (watertight Hubs page 3-9)</li> <li>▪ Corrected wiring diagram for 4 Wire (3 Blades and Fuseholders, 1 Neutral. Added "N" in box.</li> </ul>	<ul style="list-style-type: none"> <li>▪ 9/2004</li> <li>▪ 9/2004</li> <li>▪ 6/2005</li> </ul>

[Back to top](#)

[Back to top](#)

Section 3 - Safety Switches (cont.)		Change Date
 <p>Page 3-6 Heavy Duty Safety Switches</p>	<ul style="list-style-type: none"> <li>Note in NEMA Type 4, 4X, 5 header modified to read: 304 Stainless Steel (for 316 stainless see page 3-7) Dusttight, Watertight, Corrosion Resistant (watertight Hubs page 3-9)</li> <li>Corrected UL Fusible class from "R,T,J,L" to "R, J,L"</li> <li>Corrected * footnote to read: Use 60 A enclosure accessories, including electrical interlocks.</li> </ul>	<ul style="list-style-type: none"> <li>9/2004</li> <li>3/2005</li> <li>6/2005</li> </ul>
 <p>Page 3-7 Heavy Duty Safety Switches</p>	<ul style="list-style-type: none"> <li>316 Grade Stainless Steel – NEMA 3, 3R, 4, 4X, 5, 12 Table added</li> <li>H362SS photo added</li> </ul>	9/2004
 <p>Page 3-8 Heavy Duty Safety Switches</p>	Modified NEMA 3, 3R, 4, 4X, 5, 12 table heading, to read: 304 Stainless Steel Enclosure	9/2004
 <p>Page 3-9 Heavy Duty Safety Switches</p>	<ul style="list-style-type: none"> <li>Pricing corrections. Change B075, B100, B125, &amp; B150 from \$23.20 to \$22.20. Change B200 from \$42.90 to \$40.90. Change B250 from \$71.00 to \$68.00. Change B300 from \$130.00 to \$124.00</li> <li>Corrected class R fuse kits information</li> <li>Obsolete Chrome plated hubs H250CP, H300CP, H350CP, H400CP</li> </ul>	<ul style="list-style-type: none"> <li>3/2004</li> <li>3/2005</li> <li>9/2005</li> </ul>
 <p>Page 3-9 thru 3-10 Safety Switches</p>	Removed dashes from catalog numbers in footnotes	3/2006
 <p>Page 3-10 Heavy Duty Safety Switches</p>	<ul style="list-style-type: none"> <li>Corrected wire range on neutral assemblies</li> <li>Corrected terminal data</li> </ul>	<ul style="list-style-type: none"> <li>7/2004</li> <li>3/2005</li> </ul>
 <p>Page 3-11 Heavy Duty Safety Switches Accessories</p>	<ul style="list-style-type: none"> <li>For Key Interlock Systems, revised KI2 to: "K12 = 1 lock with 2 cylinders (2 keys) per switch"</li> <li>For cover Viewing Window, revised text to: "Available on 30 through 1200 ampere heavy duty switches, all NEMA Types. (Not available on NEMA 4X fiberglass reinforced polyester, Krydon® enclosures, Cast Aluminum or NEMA 7 and 9 devices.)"</li> <li>Updated Kits table heading to read: "<b>Kits – Wire size page 3-13</b>"</li> <li>For Double Lug Kits, added note: "Not UL Listed."</li> </ul>	12/2005
 <p>Page 3-12 Heavy Duty Safety Switches NEMA Type 1 and 3R – Dimensions, Lug Data</p>	<ul style="list-style-type: none"> <li>Added □ footnote on Terminal Lug Data and corrected series chart</li> <li>Corrected wire range table</li> <li>Addition of footnote symbol to Terminal Lug chart.</li> </ul>	<ul style="list-style-type: none"> <li>7/2004</li> <li>6/2005</li> <li>3/2006</li> </ul>

[Back to top](#)

[Back to top](#)

Section 3 - Safety Switches (cont.)		Change Date
  <b>Page 3-13</b> <b>Heavy Duty Safety Switches</b> <b>NEMA Types 4, 4X, 5, 7, 9 and</b> <b>12 Dimensions, Lug and</b> <b>Conduit</b>	<ul style="list-style-type: none"> <li>▪ Corrected series chart</li> <li>▪ Added catalog numbers and dimensions to existing table, for the following catalog numbers: H361SS, H362SS, H363SS, H364SS, HU361SS, HU362SS, HU363SS, &amp; HU364SS</li> </ul>	9/2004
 <b>Page 3-14 thru 3-17</b> <b>Safety Switches</b>	Multiple changes to description information and additions and deletions to charts.	3/2006
  <b>Page 3-15</b> <b>Double Throw Safety</b> <b>Switches, 240 Volt</b>	<ul style="list-style-type: none"> <li>▪ Added and corrected footnotes</li> <li>▪ Modified NEMA 4, 4X, 5 table head to read 304 Stainless Steel</li> <li>▪ Added ∇ footnote symbol next to 82254NW</li> </ul>	<ul style="list-style-type: none"> <li>▪ 9/2004</li> <li>▪ 9/2004</li> <li>▪ 6/2005</li> </ul>
 <b>Page 3-15 thru 3-17</b> <b>Safety Switches</b>	Double Throw Switches – Change in some catalog numbers, wire range and addition of new footnote.	6/2006
  <b>Page 3-16</b> <b>Double Throw Safety</b> <b>Switches, 600 Volt</b>	<ul style="list-style-type: none"> <li>▪ Modified NEMA 4, 4X, 5 table head to read 304 Stainless Steel</li> <li>▪ Corrected half shaded diamond and ∇ footnotes</li> <li>▪ Added ‡ footnote H82.... and H92... devices are NEMA 12 only, intended for use indoors only. (H92445 is NEMA 12K)</li> </ul>	<ul style="list-style-type: none"> <li>▪ 7/2004</li> <li>▪ 9/2004</li> <li>▪ 3/2005</li> </ul>
 <b>Page 3-17 Safety Switches</b> <b>Short Circuit Ratings</b>	UL Listed Short Circuit Current Ratings table, Type DTU (Series F) switches corrected to R, J, or T.	9/2005
 <b>Page 3-19 thru 3-20</b> <b>Safety Switches</b>	<ul style="list-style-type: none"> <li>▪ Correction and addition of new UL 200A, 400A and 600A switches to the charts on these pages.</li> <li>▪ Double Throw Switches – Change in some catalog numbers and dimensions.</li> </ul>	<ul style="list-style-type: none"> <li>• 3/2006</li> <li>• 6/2006</li> </ul>
  <b>Page 3-20 Double Throw</b> <b>Safety Switches</b>	<ul style="list-style-type: none"> <li>• Corrected price on B HUBS</li> <li>• Obsolete Chrome plated hubs H250CP, H300CP, H350CP, H400CP</li> </ul>	<ul style="list-style-type: none"> <li>• 3/2005</li> <li>• 9/2005</li> </ul>



[Back to top](#)

[Back to top](#)



Section 4 - Power Monitoring & Control		Change Date
 <p>Pages 4-4 &amp; 4-5 Power Meter/ Circuit Monitor</p>	<ul style="list-style-type: none"> <li>▪ Removed References to IOC26 and IOC2222</li> <li>▪ Correct Pricing on PM8M22</li> </ul>	6/2004
 <p>Page 4-6 Energy Meter, High Range</p>	<ul style="list-style-type: none"> <li>▪ Table for the High Range meters removed, as will not be offering them.</li> </ul>	6/2004
 <p>Pages 4-6 &amp; 4-7 High Range Energy Meter and Submetering</p>	Removed Tables with High Range EM, Removed PowerShare Software Section Entirely. Removed reference to Palm IR software.	6/2004
 <p>Page 4-9 The Power Server</p>	<ul style="list-style-type: none"> <li>• Catalog numbers changed to:                             <ul style="list-style-type: none"> <li>• PWRSRV710</li> <li>• PWRSRV750</li> </ul> </li> <li>• Removed References to PowerServer Model 710. Corrected Catalog Number for Power Server 750. Should be PWRSRV750 as it is loaded in Q2C.</li> </ul>	<ul style="list-style-type: none"> <li>• 6/2004</li> <li>• 6/2004</li> </ul>
 <p>Page 4-9 PowerLogic Ethernet Communications Card</p>	ECC21 photo and description added; also reference added to ECC21 on 4-4 and added reference on 4-5 to page 4-9	6/2004
 <p>Page 4-9 PowerLogic Ethernet Gateways</p>	<ul style="list-style-type: none"> <li>• Revised the PowerLogic Ethernet Gateways paragraph</li> <li>• Added the following two accessory products to the Ethernet Gateway table:                             <ul style="list-style-type: none"> <li>• Power-Over-Ethernet Injector kit for EGX100—Includes power cord, adapters, instructions. Catalog No. TCSEAV0100 List Price \$125</li> <li>• Configuration kit for EGX100—Included RJ45 to DB9F adapter, CAT5 crossover cable, instruction sheet. Catalog No. TCSEAK0100 List Price \$80</li> </ul> </li> </ul>	9/2005
 <p>Pages 4-10 &amp; 4-11 PowerLogic Software</p>	Replaced content for pages 4-10 & 4-11	9/2005
 <p>Page 4-11 SMS Software</p>	<ul style="list-style-type: none"> <li>▪ Deleted PowerServer 710 Reference</li> <li>▪ Add new Version 4 Web-Enabled Software Reference</li> </ul>	7/2004

[Back to top](#)

[Back to top](#)






Section 4 - Power Monitoring & Control (cont.)		Change Date
 <p>Page 4-18 3000 Series Controller (web-enabled) Remote Source Controller</p>	<ul style="list-style-type: none"> <li>▪ Added two new catalog numbers:                             <ul style="list-style-type: none"> <li>▪ NF3000G3 3000 Series Controller (Web enabled)</li> <li>▪ RSC16G3 Remote Source Controller</li> </ul> </li> <li>▪ Controller Type NF1000G32 corrected to NF1000G3</li> <li>▪ Part number NF4HG3 obsolete</li> <li>▪ Added Remote Mounted Controller and Remote Source Controller tables</li> </ul>	<ul style="list-style-type: none"> <li>▪ 6/2004</li> <li>▪ 11/2004</li> <li>▪ 11/2004</li> <li>▪ 11/2004</li> </ul>
 <p>Page 4-19 PowerLink G3 3000</p>	<ul style="list-style-type: none"> <li>▪ New Catalog number: NF3000G3</li> <li>▪ Revised RCS catalog number listing and added new RMC products</li> </ul>	3/2004

[Back to top](#)

Section 5 - Surge Protective Devices		Change Date
 <p>Page 5-2 Surge Protective Devices</p>	Enclosed Surge Protective Devices – Added bullet for 10 year extended warranty.	6/2006
 <p>Page 5-3 Integrally/Internally Mounted TVSS</p>	Added new OEM TVSS products	3/2005

[Back to top](#)

[Back to top](#)

Section 6 - Circuit Breakers		Change Date
 <b>Section 6</b>	<p>The phrase "Continuous Current Rating" changed to "Current Rating" in all cases where it appears as a table heading. "Continuous" is an NEC term, which implies to customers that standard rated breakers are suitable for continuous application at their rating. They are not.</p>	7/2004
 <b>Page 6-3</b> <b>QOU Circuit Breakers</b>	<p>Removed 5 kA interrupting rating at 277 volts for QOU breakers. QOU breakers are not rated for 277 volts.</p>	2/2005
 <b>Pages 6-4 thru 6-8</b> <b>Circuit Breakers</b>	<p>Changed "Instantaneous-type (3-pole)" to "Instantaneous-only (MCP)" on second line in Trip System Type"</p>	6/2005
 <b>Pages 6-6, 6-7, 6-27, 6-44, 6-50</b> <b>M Frame Breaker</b>	<p>Addition of M Frame breakers to all pages. Moved MA, MH from page 7 to page 6.</p>	3/2004
 <b>Page 6-8</b> <b>Masterpact NT Circuit Breaker</b>	<p>Addition of NT-LF and NW-LF columns</p>	5/2005
 <b>Page 6-9</b> <b>Homeline</b>	<ul style="list-style-type: none"> <li>▪ Removed sales text</li> <li>▪ Added new handle attachment.</li> </ul>	8/2004
 <b>Page 6-10</b> <b>Circuit Limiting QOT Tandem Breakers</b>	<p>Changed NEC reference from 408.15 to 408.35</p>	12/2005
 <b>Page 6-13</b> <b>OEM Mounting Bases</b>	<p>Added new catalog numbers and corrected layout</p>	7/2004
 <b>Page 6-14</b> <b>Miniature Circuit Breakers</b>	<p>Added QOU-VH products</p>	9/2005
 <b>Page 6-17</b> <b>MULTI 9 C60N UL 1077</b> <b>Supplementary Protectors</b> <b>and UL 489A Circuit Breakers</b> <b>for DC Telecommunications</b>	<p>The table heading indicates 120/240 for the UL 1077 rated C60N products. They are rated at 480Y/277. Bullets above are correct; but table heading is misleading and too restrictive.</p>	4/2004










[Back to top](#)

[Back to top](#)

Section 6 - Circuit Breakers (cont.)		Change Date
 Page 6-18 and 6-60 Circuit Breakers	Users were confused by French designations OF, SDE, SD. Revised to 1a or 1a1b or 2a2b, etc.	3/2006
  Page 6-19 Multi 9 C60N and NC100 Accessories	<ul style="list-style-type: none"> <li>▪ Replaced MSC Mounting Base info with new US Mounting Base</li> <li>▪ Wording in top table under Rotary Handle Info, 3rd line changed from "Fixed handled *** " to " Fixed handle *** "</li> </ul>	<ul style="list-style-type: none"> <li>▪ 9/2005</li> <li>▪ 12/2005</li> </ul>
 Page 6-20, 8-25 Thermal Magnetic Molded Case Circuit Breakers	FCL 2-Pole Breakers, 15-45A obsolete. Catalog numbers: FCL24015, FCL24020, FCL24025, FCL24030, FCL24035, FCL24040, FCL24045	10/2003
 Page 6-20, 8-25 Thermal Magnetic Molded Case Circuit Breakers	FCL 2-Pole Breakers, 15-45A obsolete. Catalog numbers: FCL24015, FCL24020, FCL24025, FCL24030, FCL24035, FCL24040, FCL24045	10/2003
 Page 6-21 PowerPact Q Frame Breakers	The ▲ footnote for the PowerPact Q frame breakers states that the standard lug accepts 14 AWG to 300 kcmil cable. It should be # 4 to 300kcmil.	7/2004
 Page 6-28 MICROLOGIC Trip Units	The reference to Temperature Indication is incorrect. It was deleted from the list (third bullet from the bottom under Micrologic (Power) 5.0P and 6.0P Trip Units), and from the table of features.	4/2004
 Page 6-36 Mechanical Accessories	Added new HPAFKF Lock-Off-Only for legacy F and K frame breakers	3/2005
 Page 6-37 Electrical Accessories	In shunt Trip chart, ▲ footnote added to 480 V suffix 1037	6/2005
 Page 6-40 Micrologic Trip Units	Micrologic Trip Units – Add table to this page.	6/2006
 Page 6-41 and 6-42 Powerpact	Addition of M Frame breakers, deletion of shunt trip and price changes on both pages.	3/2004







[Back to top](#)

[Back to top](#)

Section 6 - Circuit Breakers (cont.)		Change Date
 <b>Page 6-41 Powerpact P and R field-installed accessories</b>	Add these new field-installed kits (BCM, M6C and EVS)	1/2005
 <b>Page 6-42 PowerPact Electronic Trip Circuit Breakers</b>	Powerpact Padlock Attachments – Add lock ON/OFF description	6/2006
  <b>Page 6-43 Mechanical Lugs</b>	<ul style="list-style-type: none"> <li>▪ ▲ footnote should make no reference to Powerpact P frame; note only applies to R frame.</li> <li>▪ Standard lug kit for an 800A PG I-Line breaker clarified. It showed both the AL800M23K and the AL800P6K as standard. There is no breaker listed in the "Optional" column for either of these lug kits.</li> <li>▪ Added footnotes to the following catalog numbers:                             <ul style="list-style-type: none"> <li>▪ AL1200P25K, AL1200P6KU and CU1200P25K: For unit mount circuit breakers only.</li> <li>▪ AL1200P24K, AL800P6K and CU1200P24K: Does not fit onto ON end of unit mount P-frame circuit breakers.</li> </ul> </li> <li>▪ Lug for Powerpact P frame: The left-hand column indicated this lug is Standard on M and P frame. But this lug does not work on the M frame. The left hand column now has a row for M and P frame, and a second one for P frame only, in both the Aluminum and Copper sections</li> <li>▪ Lug kit AL800MA7 was moved to the MA breaker family chart</li> </ul>	<ul style="list-style-type: none"> <li>▪ 4/2004</li> <li>▪ 4/2004</li> <li>▪ 9/2005</li> <li>▪ 12/2005</li> <li>▪ 3/2006</li> </ul>
 <b>Page 6-45 Masterpact NT circuit breaker</b>	Revision to referenced catalog document number and corrections to NW and NT ratings charts	3/2004
 <b>Page 6-47 Vigirex Ground-fault Relay</b>	<ul style="list-style-type: none"> <li>▪ Replaced 33573 with 56053</li> <li>▪ Replaced 33574with 56054</li> <li>▪ Added asterisk to POA; Add asterisk to GOA;</li> <li>▪ Added ▲ footnote under Sensor table: * Not UL recognized</li> <li>▪ Also added detailed settings of Delay and Sensitivity</li> <li>▪ Add column with maximum current ratings for sensors</li> </ul>	<ul style="list-style-type: none"> <li>▪ 6/2004</li> <li>▪ 6/2004</li> <li>▪ 6/2004</li> <li>▪ 6/2004</li> <li>▪ 6/2004</li> <li>▪ 1/2005</li> </ul>
  <b>Page 6-51 Circuit breakers enclosures</b>	<ul style="list-style-type: none"> <li>▪ Corrected ◆ footnote to read: MEL100% rated breaker-short circuit rating is 50,000 AIR at 480 Vac maximum. For other voltages, see circuit breaker ratings.</li> <li>▪ Added new catalog numbers J250S, J250F, J250R, J250DS and J250AWK</li> </ul>	<ul style="list-style-type: none"> <li>▪ 6/2005</li> <li>▪ 9/2005</li> </ul>
 <b>Page 6-51 thru 6-53 Circuit Breakers</b>	Added "manually operated" to chart header for Enclosures for Walking Beams. Changed "and" to "plus" in column head on chart. Added <u>NEMA 3R and 12 are side-mount only</u> to the Enclosed Molded Case Circuit Breakers Motor-operated description.	3/2006




[Back to top](#)

[Back to top](#)

Section 6 - Circuit Breakers (cont.)		Change Date
 <b>Page 6-52</b> <b>Circuit Breaker Enclosures</b>	<ul style="list-style-type: none"> <li>▪ Added prices for factory installed ground bars</li> <li>▪ Corrected Terminal Lug Data</li> <li>▪ Corrected table head to read: Terminal Lug Data—Total Available (Line and Load) AWG/kcmil</li> <li>▪ Added H and J breakers to neutral chart.</li> <li>▪ Added PKOGTJ250 ground bar</li> <li>▪ Added J enclosures to dimensions chart</li> <li>▪ In Dimensions table, J250S and J250F lines transposed</li> </ul>	<ul style="list-style-type: none"> <li>▪ 7/2004</li> <li>▪ 3/2005</li> <li>▪ 6/2005</li> <li>▪ 9/2005</li> <li>▪ 9/2005</li> <li>▪ 9/2005</li> <li>▪ 12/2005</li> </ul>
 <b>Page 6-53</b> <b>Enclosed Molded Case Circuit Breakers</b>	<ul style="list-style-type: none"> <li>▪ Corrected price alignment with catalog number</li> <li>▪ For Enclosed Walking Beam Mechanical Interlock, update note: Specify manually or electrically operated (electrically operated factory installed only)</li> </ul>	<ul style="list-style-type: none"> <li>▪ 7/2004</li> <li>▪ 12/2005</li> </ul>
 <b>Page 6-55 through 6-60</b> <b>H and J Frame Breakers</b>	<ul style="list-style-type: none"> <li>▪ New pages added to cover the H and J Frame breakers</li> <li>▪ Changed "Instantaneous-type (3-pole)" to "Instantaneous-only (MCP)" on second line in Trip System Type"</li> </ul>	<ul style="list-style-type: none"> <li>▪ 6/2004</li> <li>▪ 6/2005</li> </ul>
 <b>Page 6-55</b> <b>PowerPact H- J- frame</b>	Updated Interrupting Ratings table	12/2005
 <b>Page 6-56</b> <b>J-frame 250 A Thermal-magnetic (600 Vac) Factory Sealed Trip Unit Suitable for Reverse Connection</b>	Updated J-frame thermal wire rating information	12/2005
 <b>Page 6-57</b> <b>J-frame 250 A Thermal-magnetic (600 Vac) Circuit Breaker Frame + Field Interchangeable Trip Unit</b>	Updated J-frame thermal wire rating information	12/2005

[Back to top](#)

[Back to top](#)

Section 6 - Circuit Breakers (cont.)		Change Date
 <p><b>Page 6-58</b>  <b>H- and J-frame Terminals and Field Installable Accessories</b></p>	<p>In Installation Accessories chart, updated DIN rail mounting kit (requires 15 mm depth on a 35 mm DIN rail)</p>	<p>12/2005</p>
 <p><b>Page 6-59</b>  <b>H- and J-frame Terminals and Field Installable Accessories</b></p>	<ul style="list-style-type: none"> <li>▪ In Mechanical Lug Kits table, updated 3 of wires for JD, JG, JJ, JL to: 1-#4 AWG Al or Cu</li> <li>▪ New photos</li> <li>▪ Added Terminal Shields for Mechanical Lugs table</li> <li>▪ Added Terminal Shields for Power Distribution Connectors table</li> </ul>	<p>12/2005</p>
 <p><b>Page 6-56, 6-57, &amp; 6-59</b>  <b>H- and J-frame Thermal-magnetic Molded Case Circuit Breakers</b></p>	<ul style="list-style-type: none"> <li>▪ Accessories and lug kit info changed</li> <li>▪ Trip &amp; Hold to Low and High changed</li> </ul>	<p>10/2004</p>







[Back to top](#)

[Back to top](#)

Section 7 - Operating Mechanism & Disconnect Switches		Change Date
 <p><b>Page 7-2</b> <b>Manual Motor Control Switches</b></p>	<p>Identification System at top of page shows the GU enclosure type as having an IP65 rating. Changed to IP55.</p>	4/2004
 <p><b>Page 7-4</b> <b>Vario Switches</b></p>	<p>Bottom dimensional table labeled "Four-Hole Mounting Dimensions" retitled "Door Mounting Switch Body Dimensions "</p>	12/2005
 <p><b>Page 7-6</b> <b>IEC Style Disconnect Switches</b></p>	<p>In the last table on the left side of the page, there are four references to GS1EERU20. The 30 Amp, 3-Pole, Class CC catalog number changed to GS1EERU30. Below that, in the description, it reads "for GS1EERU20 and GS1EERU20" this changed to "for GS1EERU20 and GS1EERU30.</p>	3/2004
 <p><b>Page 7-7</b> <b>IEC Style Disconnect Switches</b></p>	<p>Pistol Handles for Standard GS1 and LK3</p> <ul style="list-style-type: none"> <li>▪ Now Reads: GS1 30 A thru 100 A and Lk3 60 A thru 100A. Added (3" Handles). Now reads: GS1 30 A thru 100A and LK3 60 A thru 100A (3" Handles)</li> <li>▪ Now Reads: GS1 200 A thru 400 A and LK3 200A. Added (5" handles) Now reads: GS1 200A thru 400 A and LK3 200 A (5" Handles)</li> </ul>	4/2004
 <p><b>Page 7-8</b> <b>IEC Style Disconnect Switches</b></p>	<p>The descriptions for the two, side mounted auxiliary contacts are incorrect. Catalog number GS1AN22 description should be "2 N.O. &amp; N.C. Contact Block (max of two blocks - any mix)"; GS1ANT22 should be "2 N.O. &amp; N.C. Contact Block w/Test (max of two blocks - any mix)"</p>	3/2004
 <p><b>Page 7-9</b> <b>IEC Style Disconnect Switches</b></p>	<ul style="list-style-type: none"> <li>▪ Dimension corrected</li> <li>▪ Lower handle for the GS1DDU3 and GS1DU3 has a 5.0 dimension. Changed to read 3.0 and 76.2 mm.</li> </ul>	4/2004
 <p><b>Page 7-10</b> <b>IEC Style Disconnect Switches</b></p>	<ul style="list-style-type: none"> <li>▪ Dimension corrected</li> <li>▪ Handle for the GS1EU3/GS1GU3 30 A/60 AJ has a 5.0 dimension. Changed to read 3.0 and 76.2 mm</li> <li>▪ Handle for the GS1JU3, GS1 100A J has a 5.0 dimension. Changed to read 3.0 and 76.2 mm</li> </ul>	4/2004
 <p><b>Page 7-11</b> <b>IEC Style Disconnect Switches</b></p>	<ul style="list-style-type: none"> <li>▪ Dimensions corrected</li> <li>▪ Handle for the LK3GU3/LK3JU3, LK3 60 A/ 100A has a 5.0 dimension. Changed to read 3.0 and 76.2 mm.</li> </ul>	4/2004
  <p><b>Page 7-13</b> <b>Door Mounted Operating Mechanisms</b></p>	<ul style="list-style-type: none"> <li>▪ The Note under table "Electrical Interlock Kits Class 9999" changed to read "Not used with GJL, NAL, NCL, NEL, NXL, NSF, NSJ, POWERPACT C, OR POWERPACT D mechanisms; use field-installable circuit breaker interlocks instead."</li> <li>▪ Added Merlin Gerin NSF, NSJ, Powerpact C, H-and J-Frame Breakers</li> <li>▪ Added ♦ footnote to the LAL, LHL complete kits and LAL, LHL component parts to read: "Warning these operating mechanisms cannot be used with any LA/LH breaker with a MB or MT suffix"</li> <li>▪ Changed Merlin Powerpact "C" breakers to "D"</li> </ul>	<ul style="list-style-type: none"> <li>▪ 6/2004</li> <li>▪ 1/2005</li> <li>▪ 6/2005</li> <li>▪ 9/2005</li> </ul>










[Back to top](#)

[Back to top](#)

Section 7 - Operating Mechanism & Disconnect Switches (cont.)		Change Date
 <p><b>Page 7-20</b> Flexible Cable Mechanisms, bracket Mounted Disconnect Devices, &amp; Flange Mounted Variable Depth Operating Mechanism</p>	<ul style="list-style-type: none"> <li>▪ The Flexible Cable Mechanisms for Use with Square D Circuit Breakers table at the bottom of the page has some information missing. The last two columns with the heading "Cable Mechanisms with A1 Handle For Types 1, 3, 3R, 12" should include Type 4. Change heading to "Cable Mechanisms with A1 Handle For Types 1, 3, 3R, 4, 12".</li> <li>▪ Electrical Interlock Kits - class 9999 currently reads: Optional accessory for use with circuit breaker operating mechanisms listed to the left, except GJL. Changed to read Optional accessory for use with circuit breaker operating mechanisms listed to the left and the flexible cable mechanisms listed below, except GJL.</li> <li>▪ Added ♦ footnote to the LAL, LHL complete kits and LAL, LHL component parts to read: "Warning these operating mechanisms cannot be used with any LA/LH breaker with a MB or MT suffix"</li> </ul>	<ul style="list-style-type: none"> <li>▪ 3/2004</li> <li>▪ 3/2004</li> <li>▪ 6/2005</li> </ul>
 <p><b>Page 7-21</b> Flexible Cable Mechanisms</p>	<ul style="list-style-type: none"> <li>▪ Information updated in the Flexible Cable Mechanisms for Use with MERLIN GERIN Circuit Breakers paragraph at the top of the page. The first sentence in this paragraph reads; "For use with MC circuit breakers and Class 9422 A handle operators". Changed this sentence to read; For use with MG circuit breakers and Class 9422 Type A handle operators listed on page 7-17.</li> <li>▪ Changed the heading on the top of the page as follows: Flexible Cable Mechanisms for Use With MERLIN GERIN and Powerpact H-and J-frame three pole Circuit Breakers. For use with Class 9422 A handle operators especially designed for tall, deep enclosures where placement flexibility is required.</li> <li>▪ Added: Powerpact H-and J-frame under MG-NSF for the 3 pole 250A mechanisms only (CSF30, CSF50, CSF70, CSF10)</li> </ul>	<ul style="list-style-type: none"> <li>▪ 3/2004</li> <li>▪ 1/2005</li> <li>▪ 1/2005</li> </ul>
 <p><b>Page 7-22</b> NEMA Style Operating Mechanism</p>	<p>The circuit breaker operating mechanism for MAL and MHL breakers states the Frame Size as 1000 amps. This is incorrect, as the MAL breaker is a 1200A frame breaker. Changed the rating in the column headed "Frame Size (Amps)" to 1200.</p>	<p>3/2004</p>
 <p><b>Page 7-22</b> 9422 Flange Mounted, Variable Depth Operating Mechanism</p>	<ul style="list-style-type: none"> <li>▪ Changed as follows:                             <ul style="list-style-type: none"> <li>▪ MERLIN GERIN, Powerpact H- and J-Frame 3 Pole Circuit Breakers.</li> <li>▪ Added Powerpact H-and J-frame to MG-NSF 3 pole, 250A 9422RQ1 operating mechanism</li> </ul> </li> <li>▪ Added ♦ footnote to the LAL, LHL complete kits and LAL, LHL component parts to read: "Warning these operating mechanisms cannot be used with any LA/LH breaker with a MB or MT suffix"</li> </ul>	<ul style="list-style-type: none"> <li>▪ 1/2005</li> <li>▪ 6/2005</li> </ul>
  <p><b>Page 7-23</b> Flange Mounted Disconnect Switches</p>	<ul style="list-style-type: none"> <li>▪ Air Valve Interlock. Changed Schrader Bellows in the first sentence to PARKER. Changed contact information to: PARKER at CPARKER@PARKER.COM or call 1-800-272-7537.in the sentence below the table</li> <li>▪ Following products are obsolete: M08541890, M08561890, M088581890, M09091885, &amp; M08591885</li> </ul>	<ul style="list-style-type: none"> <li>▪ 9/2005</li> <li>▪ 9/2005</li> </ul>








[Back to top](#)

[Back to top](#)

Section 8 - Panelboards		Change Date
 <b>All Section 8 pages</b>	The phrase "Continuous Current Rating" changed to "Current Rating" in all cases where it appears as a table heading. "Continuous" is an NEC term, which implies to customers that standard rated breakers are suitable for continuous application at their rating. They are not.	7/2004
 <b>Pages 8-2 &amp; 8-3</b> <b>Series Ratings for NQOD, NF, &amp; I-Line Panelboards</b>	Updated Series Ratings	9/2005
  <b>Pages 8-6, 8-8, 8-9, 8-11, 8-14, 8-16, 8-19, &amp; 8-23</b>	Updated H and J-frame pricing along with changes regarding removal of handle extension (YL suffix).	9/2005
 <b>Section 8, Pages 1, 2, 3, 4, 5, 6, 8, 9, 11, 12, 14, 15, 16, 18, 19, 20, 21, 22, 23, 24, 25, 28, 32, 33, 34, 36, 39, 41, 42</b> <b>H &amp; J-frame and MG/MJ circuit breakers</b>	<ul style="list-style-type: none"> <li>▪ Addition of H and J-frame circuit breakers in NQOD, NF and I-LINE panelboards</li> <li>▪ Addition of MG/MJ circuit breakers in I-LINE panelboards</li> </ul>	12/2004
 <b>Pages 8-6 &amp; 8-8</b> <b>NQOD panels</b>	The references to QB,QD,QG,QJ in the Main Circuit Breaker Adapter Kits table changed to "QBL,QDL,QGL,QJL "	3/2004
  <b>Pages 8-17</b> <b>ED, EG, EJ branch circuit breakers for Merchandised NF Panelboards</b>	<ul style="list-style-type: none"> <li>▪ Added HID designation for 35 through 50A</li> <li>▪ Added table of new ExB-EPDs below E-Frame breakers.</li> <li>▪ Added new ★ footnote.</li> <li>▪ Added new BA accessory package to existing list (aux switch, shunt trip, etc.).</li> </ul>	<ul style="list-style-type: none"> <li>▪ 10/2004</li> <li>▪ 5/2004</li> <li>▪ 5/2004</li> <li>▪ 5/2004</li> <li>▪ 5/2004</li> </ul>
 <b>Pages 8-22, 23, 24, 29, 32, 33</b> <b>MG and MJ branch breakers added into I-LINE</b>	<ul style="list-style-type: none"> <li>▪ Substantial changes to add MG and MJ branch breakers into I-LINE:                             <ul style="list-style-type: none"> <li>▪ Pages 8-22 and 8-23: added MG and MJ branch breakers into I-LINE schematic sketches</li> <li>▪ Page 8-24: Added new sub feed lug kit, correct error</li> <li>▪ Page 8-29: Added attached branch breakers sentences 8-32 and 8-33: Add MG and MJ to existing charts</li> </ul> </li> </ul>	6/2004


[Back to top](#)

[Back to top](#)






Section 8 - Panelboards (cont.)		Change Date
 <p><b>Pages 8-22 and 8-23</b> <b>I-line Panelboards</b></p>	<p><b>Page 8-22:</b> Three diagrams on L/H side of page: Above top diagram, changed 100 A max to 150 A max. New text reads, "150 A max. branch circuit breaker FA, FH, ..."</p> <p><b>Page 8-23:</b> Three diagrams on L/H side of page: 1st diagram: TYPE HCP (Main Lugs Only) - delete "(Main Lugs Only)" 2nd diagram: TYPE HCP - delete this diagram 3rd diagram: TYPE HCR-U - leave as is. <b>EFFECT OF CHANGE:</b> Two diagrams instead of three, <b>TYPE HCP</b> and <b>TYPE HCR-U</b>.</p>	1/2005
 <p><b>Page 8-23 I-LINE</b> <b>Merchandized Panelboards</b></p>	<p>CB/SF Lug Kit Mounting Inch Requirements – Add KC breaker to this chart.</p>	6/2006
  <p><b>Page 8-25</b> <b>I-LINE Panel breakers</b></p>	<ul style="list-style-type: none"> <li>▪ The QO header changed to read, "Order QO plug-on circuit breakers from Section 6 and QO bolt-on circuit breakers from Section 8."</li> <li>▪ In the second table on the left side of the page the upper row's contents rearranged to have the data (FA14035A etc.) in the "1-pole" column.</li> <li>▪ Deleted the following catalog numbers from the page, as they are obsolete: FC24015, FC24020, FC24025 FC24030, FC24035 FC24040, FC24045</li> </ul>	<ul style="list-style-type: none"> <li>▪ 3/2004</li> <li>▪ 3/2004</li> <li>▪ 10/2004</li> </ul>
 <p><b>Page 8-29</b> <b>Powerpact M &amp; P Frame</b> <b>Circuit Breakers</b></p>	<ul style="list-style-type: none"> <li>▪ Moved rule to price break location</li> <li>▪ combined headers to save space</li> </ul>	10/2004
 <p><b>Page 8-35</b> <b>QMB Fusible Switches</b></p>	<p>Under catalog number QMB60R and QMB36R, catalog number HRK1020 added, with the price 31.80.</p>	7/2004
 <p><b>Page 8-43</b> <b>H and J Frame Breakers</b></p>	<ul style="list-style-type: none"> <li>▪ New PowerPact H- and J- page</li> <li>▪ In the J-frame AC Magnetic Trip Setting column, changed words "Hold" and "Trip" to "Low" and "High".</li> <li>▪ Added ♦ footnote at bottom of page "UL magnetic trip setting tolerances are -20%/ +30% (Low) and -20%/ +30% (High) from the nominal values shown."</li> </ul>	<ul style="list-style-type: none"> <li>▪ 1/2005</li> <li>▪ 12/2005</li> <li>▪ 12/2005</li> </ul>

[Back to top](#)

[Back to top](#)








Section 9 - Switchboards and Switchgear		Change Date
 <b>Page 9-6</b> <b>SPEED-D Switchboards</b>	<ul style="list-style-type: none"> <li>Added Table D, I-Line Distribution Section, with new catalog numbers.</li> <li>Changed headings on existing Tables D, E and F to Tables E, F, and G.</li> </ul>	11/2004

[Back to top](#)

Section 10 - Busway		Change Date
 <b>Page 10-2, 10-3 PowerBus 225</b>	Clarified all "configurations" to indicate Ground ("G") and show 'empty' bar spaces	6/2004
 <b>Page 10-3 PowerBus 225 Plug-In Units</b>	Wording changed in 120 V Factory assembled units—1-pole QO/QOB circuit breakers with NEMA 5-15R or 5-20R receptacles table.	9/2004
 <b>Page 10-5 I-LINE II Busway 800 A-5000. 3Ø4W with Integral Ground Bus</b>	<ul style="list-style-type: none"> <li>Bulbar configuration illustration revised.</li> <li>In 3Ø4W table, part number AF2310GLFM12 changed to AF2510GLFM12</li> </ul>	6/2004
 <b>Page 10-5 Busway Accessories (Hangers)</b>	Under: "Horizontal Mount Busway" - "Edgewise"; the third item down (HF53E) is incorrect. Changed to read exactly same as item beneath it (HF58E)	1/2005
 <b>Page 10-9 Plug-In Units Class 5615, 5630</b>	<ul style="list-style-type: none"> <li>Photo at top left of page corrected</li> <li>Circuit Breaker Type--Standard Interrupting Capacity table revised</li> </ul>	6/2004






[Back to top](#)


[Back to top](#)

Section 11 - Wire Management		Change Date
 <a href="#">Page 11-4 Poke-Thru fittings</a>	Product Line Obsolete	3/2005
 <a href="#">Page 11-5 Subway</a>	Overlay screen added to page - Obsolete September 2005	9/2005
 <a href="#">Page 11-6 Subway</a>	Overlay screen added to page - Obsolete September 2005	9/2005
 <a href="#">Page 11-7 Subway</a>	Overlay screen added to page - Obsolete September 2005	9/2005
 <a href="#">Page 11-8 Subway</a>	Overlay screen added to page - Obsolete September 2005. The Afterset Inserts are still available. Chart moved to page 11-10	9/2005
 <a href="#">Page 11-9 Subway</a>	Overlay screen added to page - Obsolete September 2005	9/2005
 <a href="#">Page 11-10 Subway</a>	Afterset Inserts chart moved from page 11-8 to page 11-10. These are still available.	9/2005

[Back to top](#)










[Back to top](#)

Section 12 - Transformers		Change Date
 <a href="#">Page 12-1</a> <a href="#">Table of Contents</a>	The page number for Low Voltage Drive Isolation corrected to 12-5 ( not 12-6 as shown)	12/2005
 <a href="#">Page 12-2</a> <a href="#">Single Phase Units</a>	Single Phase Units- Second group. <ul style="list-style-type: none"> <li>▪ 1.5 kVa part number reads: 3S1F</li> <li>▪ Should read: 1.5 kVa 1.5S1F</li> </ul>	3/2004
 <a href="#">Page 12-4 Watchdog Low Temperature Rise Transformers</a>	Watchdog Low Temperature Rise Transformers <ul style="list-style-type: none"> <li>▪ Third and last tables changed from 4-2.5%2+4- to read: 6-2.5% 2+4-</li> <li>▪ All taps on these transformers should read 6-2.5%2+4-</li> </ul>	3/2004
 <a href="#">Page 12-6</a> <a href="#">Dry Type 600 Volts and Below K-Rated</a>	Second column-all of the part numbers in this section should not be bold. (Bold means stock) <ol style="list-style-type: none"> <li>1. Under K-4-copper windings 150° C rise:                             <ul style="list-style-type: none"> <li>▪ Changed enclosure on part number 15T3HISCUNL from 18D to 17D</li> </ul> </li> <li>2. Under k-13-copper windings, 150° C rise                             <ul style="list-style-type: none"> <li>▪ Changed enclosure on part number 15T3HISCUNLP from 18D TO 17D</li> <li>▪ Changed enclosure on part number 15THISCUNLP from 22D to 21D</li> </ul> </li> <li>3. Under K-4 Rated - Cooper Windings, 115°C rise:                             <ul style="list-style-type: none"> <li>▪ Changed enclosure on part number 15T3HFISCUNL from 18D to 17D.</li> </ul> </li> <li>4. Under k-13-copper windings 115°C Rise:                             <ul style="list-style-type: none"> <li>▪ Changed enclosure on part number 15T3HFISCUNLP from 18D to 17D</li> </ul> </li> </ol>	4/2004
 <a href="#">Page 12-8</a> <a href="#">NEMA 4X Single Phase</a> <a href="#">Back to top</a>	Under the NEMA 4X Single Phase Table: changed 7 7S40F4XSS to read: 7.5 7S40F4XSS	3/2004

Section 13 - Medical Products		Change Date
 <a href="#">Page 13-1</a> <a href="#">Table of Contents</a>	CIC number corrected, from 800-SquareD to 888-SquareD	9/2003











[Back to top](#)

[Back to top](#)

Section 14 - NEMA Contactors and Starters		Change Date
 <b>Page 14-2</b> <b>Manual Starters</b>	<ul style="list-style-type: none"> <li>Header modified to indicate this is a 16A rated starter.</li> <li>Added a note under the footnotes on the center of the page to read: "For green pilot light add the letter "G" to the catalog number (i.e. 2510FG2PG)"</li> <li>Under horsepower table at bottom right of page, the following was added: "Continuous Current Rating 16A"</li> </ul>	<ul style="list-style-type: none"> <li>6/2004</li> <li>1/2005</li> <li>1/2005</li> </ul>
 <b>Page 14-3</b> <b>2510 Manual Switches</b>	<ul style="list-style-type: none"> <li>Header modified to indicate this is a 30A rated switch.</li> <li>Added a note under the footnotes on the center of the page to read: "For green pilot light add the letter "G" to the catalog number (i.e. 2510KW2CG)"</li> <li>Below horsepower ratings at the lower left corner of page, added the following: "Continuous Current Rating 30A at 600VAC Maximum."</li> </ul>	<ul style="list-style-type: none"> <li>6/2004</li> <li>1/2005</li> <li>1/2005</li> </ul>
 <b>Page 14-6</b> <b>Manual Starters</b>	<ul style="list-style-type: none"> <li>The UL File numbers referenced at the bottom of the page are incorrect. "All Except NEMA 7 &amp; 9" should be UL File # E42243, CCN remains the same. "NEMA 7 &amp; 9 Only" should be UL File # E 58760, CCN NPXZ.</li> <li>The ▲ footnote second sentence reads, "NEMA 4X, 7 &amp; 9 enclosures ...". The reference to 4X deleted, so the sentence now reads, "NEMA 7 &amp; 9 enclosures....".</li> <li>Change NEMA 7 &amp; 9 Enclosure Column Header to: NEMA 7 &amp; 9 For Hazardous Locations <b>Div. 1 &amp; 2</b> Class I – Groups C, D Class II –Groups E, F &amp; G</li> </ul>	<ul style="list-style-type: none"> <li>6/2004</li> <li>6/2004</li> <li>3/2006</li> </ul>
 <b>Page 14-9</b> <b>Manual Starters and Switches</b>	<ul style="list-style-type: none"> <li>Under "Modifications (Type M &amp; T only) at the bottom left side of the page, under the Δ footnote for Form P11, the example catalog number changed from 2510NBG1V02P11 to 2510MBG1V02P11.</li> <li>The enclosures table at the bottom right side of the clarified: 9991EN1 applies only to Types F and K; 9991MG1 applies only to Types M-Sizes M0 &amp; M1; 9991MG2 applies only to Type M-Size M1P; 9991FE1 applies only to Types FO; 9991KE1 applies only to Types KO</li> </ul>	<p>3/2004</p>
 <b>Page 14-13</b> <b>8502 NEMA contactors</b>	<p>The NEMA 1 column heading includes the phrase, "Div. 1 &amp; 2". This is incorrect and was deleted.</p>	<p>6/2004</p>
  <b>Page 14-15</b> <b>8536 Starters</b>	<ul style="list-style-type: none"> <li>The footnotes at very bottom of page tweaked. Example catalog numbers changed from Class 8502 to 8536 for both the ★ &amp; ▼ footnotes.</li> <li>Inserted a statement that Form S must be specified for 120V. Currently, this is only noted for the 24V footnote</li> <li>Changed list price on catalog number 8536SGW11 from \$8,924.00 to \$10,530.00</li> </ul>	<ul style="list-style-type: none"> <li>6/2004</li> <li>6/2004</li> <li>5/2005</li> </ul>
 <b>Page 14-16</b> <b>NEMA Starters</b>	<ul style="list-style-type: none"> <li>Added the following statement to the ▲ footnote: Sizes 5 through 7 NEMA 12 enclosures do not carry the dual NEMA 12/3R rating. They are NEMA 12 only.</li> <li>The ◆ footnote at bottom of table uses incorrect sample catalog number. Change 8502 to 8536.</li> </ul>	<p>6/2004</p>
 <b>Page 14-16 8536 Full Voltage Starters-NEMA Rated</b>	<p>Eliminated:</p> <ul style="list-style-type: none"> <li>NEMA 9 column (second from right) and all entries within the column.</li> <li>The triangle foot note</li> </ul>	<p>1/2005</p>











[Back to top](#)

[Back to top](#)

Section 14 - NEMA Contactors and Starters (cont.)		Change Date
 Page 14-17 8536 Starters	<ul style="list-style-type: none"> <li>▪ Footnotes at very bottom of page tweaked. Example catalog numbers changed from Class 8502 to 8536 for both the black star and black upside down triangle.</li> <li>▪ Inserted a statement that Form S must be specified for 120V. Currently, this is only noted for the 24V footnote.</li> <li>▪ 2 pole FVNR starter. For a 10hp 240v 2p 1ph application, the 8536SEO6 etc. added to the bottom of the top table</li> </ul>	<ul style="list-style-type: none"> <li>• 6/2004</li> <li>• 6/2004</li> <li>• 9/2005</li> </ul>
 Page 14-18 8536 Starters	The ▲ footnote at bottom of table uses incorrect sample catalog number. Changed "8502" to "8536."	6/2004
 Page 14-18 8536 Full Voltage Starters - NEMA Rated	Eliminated NEMA 9 column (second from right) and all entries within the column. The inverted triangle footnote also eliminated.	9/2005
 Page 14-19 8536 Starters	Footnotes at very bottom of page tweaked. For the ▼ footnote, the example catalog numbers changed from Class "8502" to "8536."	6/2004
 Page 14-21 8502/8536 Dimensions	First table for open style 8502 and 8536; size 2; Type SDO; 2 & 3-pole - dimension A is incorrect. Changed to 4 5/16, not 4 15/16.	6/2004
 Page 14-26 Vacuum Contactors 8502 Type V	The selection table had some incorrect horsepower ratings and erroneously omitted voltages above 575V	6/2004
 Pages 14-32, 14-33, 14-34, Combination Starters	The Circuit Breaker Adjustment Range column heading reads (See page 6-26). The page number is incorrect - changed to 6-34.	4/2004
 Page 14-34 Combination Starters-NEMA Rated	Corrected the ■ footnote in the middle of page - deleted (\$285. adder)	4/2004
 Page 14-39 Combination Starters-NEMA Rated	Changed the ▲ footnote to read: "Dimensions also for Form F4T (standard control transformer). Form F4T11 (100VA extra capacity) and Form F4T12 (200VA extra capacity) could require the use of an oversized enclosure. Refer to control transformer selection table on page 14-38."	5/2005
 Page 14-44 8630 YD starters	In the "How to Order" example at the bottom right, the description corrected to read 100hp, 480V line, 480V <i>common</i> control, 60 hz	10/2004

[Back to top](#)

[Back to top](#)

Section 14 - NEMA Contactors and Starters (cont.)		Change Date
 Page 14-45 8630 YD starters	In the "How to Order" example at the bottom right, the description corrected to read 100hp, 480V line , 120v <i>transformer</i> control , 60 hz	10/2004
 Page 14-46 8640 Part Winding Starters	In the "How to Order" example at the bottom right, the description corrected to read 100hp, 480V line , 480V <i>common</i> control , 60 hz	10/2004
 Page 14-64 Multispeed Magnetic Starters	Changed enclosure type header: <b>NEMA 4</b> Watertight and Dustight Enclosure (Stainless Steel)... To <b>NEMA 4 &amp; 4X</b> ...	12/2005
 Page 14-65 Two Speed Combination Starters	<ul style="list-style-type: none"> <li>▪ All devices with Fuse Clip Size Amps of 30. Added footnote mark next to all the 30 amp fuse clip (8 total) devices indicating the following: "When separate control is specified, use v8x voltage codes to specify motor and control voltages."</li> <li>▪ Changed enclosure type header: <b>NEMA 4</b> Watertight and Dustight Enclosure (Stainless Steel)... To <b>NEMA 4 &amp; 4X</b> ...</li> </ul>	<ul style="list-style-type: none"> <li>▪ 5/2005</li> <li>▪ 12/2005</li> </ul>
 Page 14-69 8903 Lighting Contactors	Clarification is required to the Power Pole kit table. LO60 & LXO60 - add 1-pole kits only, 1 on each side, for converting to 8-pole. To maintain proper operation, it cannot be converted to greater than 8-pole contactor. LO80 & LXO80 - use single-pole kits, 1 on each side, for converting to 10-pole and use two-pole kits, 1 on each side, for converting to 12-pole. LO1000 & LXO1000 - remove existing single pole kit and install two-pole kits, 1 on each side, for converting to 12-pole.	3/2004
 Page 14-70 Lighting Contactors	Switch photo placement on page revised to avoid confusion. Each photo is now to the left of the respective table	1/2005
 Page 14-73 Lighting Control	<ul style="list-style-type: none"> <li>▪ The AC Coil Voltage Codes table corrected; 120 V02 / 208 V38 changed to 120/208 V38</li> <li>▪ AC Coil Voltage Codes table should read:                      V02                      V08                      240/277 V39                      480 V28</li> </ul>	<ul style="list-style-type: none"> <li>▪ 3/2004</li> <li>▪ 1/2005</li> </ul>
 Page 14-74 8903 Factory Modifications	Form G4 is valid only for Standard Mechanically Held contactors. Therefore, there should be a check mark only in the Used On, Std., Mech. Held. column while the other 4 columns are to be blank.	3/2004
  Page 14-74 8903 Lighting Control Modification Forms	<ul style="list-style-type: none"> <li>▪ Changed Pricing in Description for Form C and C6:                             <ul style="list-style-type: none"> <li>▪ Form C now reads: <b>(example: CC33). Add \$266. (C33) + \$224. (C) = \$490.</b></li> <li>▪ Form C6 now reads: <b>(example: C33C6). Add \$266. (C33) + \$224. (C6) = \$490.</b></li> </ul> </li> <li>▪ Form R62 for Type L 30 Amp Devices -- changed List Price from \$435.00 to \$485.00</li> </ul>	<ul style="list-style-type: none"> <li>▪ 1/2005</li> <li>▪ 5/2005</li> </ul>










[Back to top](#)

[Back to top](#)

Section 14 - NEMA Contactors and Starters (cont.)		Change Date
 <b>Page 14-75</b> <b>Lighting Control Field Mod</b>	<p>This catalog number for the Internal Operator Mounting Bracket, Form G53, is wrong all across the page. Changed it to 3010215901.</p>	6/2004
 <b>Page 14-78</b> <b>NEMA 4/4X Lighting Control</b>	<p>The NEMA 4/4X dimensions shown on this page are for stainless steel enclosures only. Make a note of this fact and add a footnote to use the size 2 NEMA 4/4X dimensions on page 14-22 for the glass polyester enclosures.</p>	3/2004
 <b>Page 14-81</b> <b>8910 DP Contactors</b>	<p>The resistive load amperes for the 50A 2 &amp; 3 pole contactor changed from 62A to 65A.</p>	10/2004
 <b>Page 14-82</b> <b>8910 DP Contactors</b>	<p>Added the contact rating to the right of the heading "Auxiliary Contacts " in the second table down</p>	10/2004
 <b>Page 14-88</b> <b>NEMA/Definite Purpose Type Contactors &amp; Starters</b>	<p>Added (NEMA Sizes 0 - 4 only) for Form B12. It now reads: Substitute Class 10 IEC overload relay - state motor hp (NEMA Sizes 0 - 4 only)</p>	3/2006
 <b>Page 14-89</b> <b>Well-Guard Pump Panel</b>	<p>Part Winding Type Combination Fusible disconnect Type. The fifth catalog number from the top was listed as MG3VO3. changed to read MG3MV03.</p>	3/2004
 <b>Page 14-91</b> <b>NEMA/Definite Purpose Type Contactors &amp; Starters</b>	<p>Changed the Circuit Breaker amp rating for the 480V, 10hp, NEMA size 1 CCG20, CCW20 and CCA20 from 30 to 25.</p>	3/2006
  <b>Page 14-98</b> <b>Thermal Overload Relays</b>	<ul style="list-style-type: none"> <li>▪ The "solid black box" (with number of poles) and the associated footnote removed.</li> <li>▪ Deleted the single pole non-compensated DA and GA overloads, as these are obsolete. Added DA2 and GA2 to the Compensated table for the size 00,0,1 and the 2 respectively.</li> </ul>	6/2004
 <b>Page 14-100</b> <b>Thermal Overload Relays</b>	<p>At the top of the page there are 2 dimensional drawings that reference the same catalog numbers; they're both labeled as "Types 9065SEO9 and 9065SEO9B2". The one at the top left relabeled "Types 9065SEO6 and SEO6B2".</p>	4/2004
 <b>Page 14-101</b> <b>Thermal Overload Relays- NEMA Rated</b>	<p>In the Note for the NEMA Size 5 SSOLR, the last line changed from "V500 overload relay assemblies" to "NEMA Type "S" Size 5 starters and only for melting alloy and bimetallic overload relay assemblies."</p>	6/2006









[Back to top](#)

[Back to top](#)

Section 14 - NEMA Contactors and Starters (cont.)		Change Date
 Page 14-103 Separate Enclosures	Under NEMA1 Selection Table 8903SQO the SFG8 shows a $\Delta$ footnote. This footnote mark removed for this particular product	10/2004
 Page 14-109 Factory Modifications	Form G12, Change list price to \$20.00 (twice on the page).	3/2004
 Page 14-111 Factory Modifications	<ul style="list-style-type: none"> <li>▪ Middle of the page. Under Special Note for Class 8810 devices: Single Winding, 460V, Constant Horsepower changed to read: Single Winding, 460 V, Constant or Variable Torque.</li> <li>▪ In Form Description paragraph, Catalog Number to Order: 8810SFO1V02 FORM S H20 H202 corrected to read 8810SFO1V02FORM S H202 H20</li> </ul>	3/2004
 Page 14-112 Factory Modifications	<ul style="list-style-type: none"> <li>▪ Form G50 and G56 - these are now available in increments of 5 only. Wording changed in the ordering example in the footnote.</li> <li>▪ The second and 4th rows of the top table ( MOTOR LOGIC Plus ) removed, as "Add Communication Module" is no longer a factory modification</li> </ul>	<ul style="list-style-type: none"> <li>▪ 3/2004</li> <li>▪ 5/2005</li> </ul>
 Page 14-113 Factory Modifications	Forms K35 and K36 are obsolete. Removed	4/2004
 Page 14-116 Factory Modifications	<ul style="list-style-type: none"> <li>▪ Form G50 and G56 - these are now available in increments of 5 only. Wording changed in the ordering example in the footnote.</li> <li>▪ Factory modifications at top of page Class 8640 ONLY. Delete the following Form: Non-Fusible disconnect switch..... Y792 for all enclosures Type 1, 4 and 12 with all of its pricing.</li> </ul>	<ul style="list-style-type: none"> <li>▪ 3/2004</li> <li>▪ 6/2006</li> </ul>
 Page 14-119 Magnetic Coils	<ul style="list-style-type: none"> <li>▪ The AC Coil Voltage Codes table corrected; 120 V02 / 208 V38 changed to 120/208 V38</li> <li>▪ In the Replacement Coil for 8903 Panel Board at the bottom of the page, the 120 V 9998PBV02 doesn't exist. Deleted and the voltage for the 9998PBV38 changed to 120/208 V.</li> <li>▪ In Table 1, deleted Type A 1E, 1D, 5DE and Type B ▲, R rows. For Type A, deleted "All Others."</li> <li>▪ In Table 2, deleted 8508 (Contactor) row.</li> <li>▪ In the replacement coil table:                             <ul style="list-style-type: none"> <li>▪ Changed 120/208 V to 120V and revised catalog number to 9998PBV02</li> <li>▪ Added a row for 208 V solenoid (catalog number 9998PBV08)</li> </ul> </li> </ul>	<ul style="list-style-type: none"> <li>▪ 3/2004</li> <li>▪ 3/2004</li> <li>▪ 9/2005</li> <li>▪ 9/2005</li> <li>▪ 9/2005</li> </ul>
 Page 14-120 Replacement Parts Kits	<ul style="list-style-type: none"> <li>▪ Replacement contact added to the 9998 selection tables.</li> <li>▪ In the lower right table marked 8910, 8911 and 8965 Kits, 2 columns added for the 8911 and 8965 info. To the right of DPA_20A thru DPA_90A .....a column added listing DPSO1 thru 9. To the right of this new column and DPSO1 thru 6 ..... a column added listing DPR1 thru 6.</li> </ul>	<ul style="list-style-type: none"> <li>▪ 3/2004</li> <li>▪ 11/2004</li> </ul>
 Page 14-120 8910 Definite Purpose Contactors	Class 8910, 8911, 8965 Replacement Contacts table. For the DRC9 kit, changed DPA_80A to DPA_90A. For the DRC12 kit, changed DPA_90A to DPA_120A.	3/2004





[Back to top](#)

[Back to top](#)


Section 14 - NEMA Contactors and Starters (cont.)		Change Date
 <p><b>Page 14-121</b> <b>Replacement Parts Kits</b></p>	<p>In the paragraph at the top of the page, the third line reads, "Class 9065 Type M melting..." . Delete reference to Type M so that it reads, "...Class 9065 melting alloy..."</p>	3/2004
  <p><b>Page 14-123</b> <b>Accessories, Auxiliary Contacts Class 9999</b></p>	<ul style="list-style-type: none"> <li>▪ Auxiliary contacts listed for obsolete Class 8910 &amp; Class 8911 Types H, K, L, M, N, P &amp; Q contactors are also obsolete and no longer available.</li> <li>▪ Auxiliary contacts listed for obsolete Class 8965 Types JO4, JO5, JO6, JO7, SO, TO, UO, VO, VSO, VTO contactors are also obsolete and no longer available.</li> <li>▪ Removed catalog reference to SK3 &amp; SK4 inside the "Maximum Ratings for Type S Auxiliary Contacts and Timers" table located in the center of page. Obsolete.</li> <li>▪ Changed title Auxiliary Contact Kit Selection Table, located in lower left hand corner, from "Class 8502, 8536, Types C and S" to read "Class 8502, 8536 Type S".</li> </ul>	3/2005
 <p><b>Page 14-125</b> <b>Factory Modifications</b></p>	<p>9999 SK3 and SK4 are obsolete. Deleted the Timer Attachment table.</p>	4/2004
 <p><b>Page 14-128</b> <b>9999 Fuse Kits</b></p>	<p>List price changes:</p> <ul style="list-style-type: none"> <li>▪ 9999SF1 from \$33.30 to \$59.00</li> <li>▪ 9999SF2 from \$41.10 to \$66.00</li> <li>▪ 9999SF11 from \$19.10 to \$29.50</li> </ul>	9/2003
 <p><b>Page 14-130</b> <b>Thermal Unit Selection</b></p>	<p>The thermal unit selection chart: footnote symbol added to Size 5, Series B, with a corresponding footnote with the following instructions; "Divide the motor FLC by 60 and use this quotient to select the appropriate thermal units."</p>	4/2004
 <p><b>Page 14-130</b> <b>Thermal Unit Selection</b></p>	<p>Under Class 8536, Type SH: Series B added</p>	9/2003
 <p><b>Page 14-131</b> <b>Thermal Unit Selection</b></p>	<ul style="list-style-type: none"> <li>▪ Under Class 8536, Type SH: Series B added</li> <li>▪ The thermal unit selection chart: footnote symbol added to Size 5, Series B, with a corresponding footnote with the following instructions; "Divide the motor FLC by 60 and use this quotient to select the appropriate thermal units."</li> </ul>	3/2004

[Back to top](#)








[Back to top](#)

Section 14 - NEMA Contactors and Starters (cont.)		Change Date
 <p><b>Page 14-133 Factory Modifications</b></p>	<p>(R17x) has changed. Reference to R17x deleted. Only 4 and 8 pole relays available.</p> <p>Added:</p> <ul style="list-style-type: none"> <li>▪ R174 (NEMA 1,12) \$323 all sizes</li> <li>▪ R174 (NEMA 4,4X) \$494 all sizes</li> <li>▪ R174 (NEMA 7,9) \$494 sizes 0-5</li> <li>▪ R178 (NEMA 1,12) \$494 all sizes</li> <li>▪ R178 (NEMA 4,4X) \$741 all sizes</li> <li>▪ R178 (NEMA 7,9) \$741 sizes 0-5</li> </ul> <p>Deleted Form K and replace with:</p> <ul style="list-style-type: none"> <li>▪ K25 - On delay - .1 sec to 1 min \$798 NEMA 1 all sizes; \$1,044 NEMA 3R, 4, 4X, 12 all sizes; \$1044 NEMA 7/9 sizes 0 - 5, sizes 6 - 7 Not available.</li> <li>▪ K26 - Off delay - .1 sec to 1 min \$798 NEMA 1 all sizes; \$1,044 NEMA 3R, 4, 4X, 12 all sizes; \$1044 NEMA 7/9 sizes 0 - 5, sizes 6 - 7 Not available.</li> <li>▪ K37 - On delay - 1 - 3 min \$798 NEMA 1, 3R, 4, 12 all sizes; \$798.00 NEMA 4X, 7/9 sizes 0 - 5, sizes 6 - 7 Not available.</li> <li>▪ K38 - Off delay - 1 - 3 min \$798 NEMA 1, 3R, 4, 12 all sizes; \$798.00 NEMA 4X, 7/9 sizes 0 - 5, sizes 6 - 7 Not available.</li> <li>▪ Form K1 - replace by the K10xx form.</li> <li>▪ Form G911, G913, and G914 - no longer available.</li> <li>▪ Form Y31 - obsolete, use G13 in its place.</li> </ul>	<p>9/2003</p>
 <p><b>Pages 14-134 thru 14-152 Thermal Unit Selection</b></p>	<p>Tables 1 - 150: For heater numbers beginning with A, AF, AR, AU, B, C, CC, and DD (all except E) without a decimal point, added .0 on the end. For example, B14 changed to B14.0, B22 to B22.0, etc.</p>	<p>11/2004</p>
 <p><b>Page 14-137 Thermal Unit Selection Table</b></p>	<p>The last thermal unit in selection table 27 is wrong. For 41.6 - 45.0 amps, the correct thermal unit is AR94, not AR93.</p>	<p>11/2004</p>
 <p><b>Page 14-139 Thermal Units</b></p>	<p>Correction to Table 53: 1 T.U. column. Value currently reads 1.29-1.14. Changed to 1.29 - 1.41</p>	<p>1/2005</p>

[Back to top](#)






Section 15 - Motor Control Centers		Change Date
 <p><b>Page 15-6 Motor Control Centers Merchandised Units</b></p>	<ul style="list-style-type: none"> <li>▪ In <b>Circuit Breaker Branch Feeder Units</b> Ratings: 480 V, NEMA Type 12, 65,000 AIR table, revised unit dimensions</li> <li>▪ Deleted ♦ footnote</li> </ul>	<p>12/2005</p>

[Back to top](#)

Section 16 - IEC Contactors & Starters		Change Date
 <p>Page 16-2 Enclosed Combination Starters</p>	<ul style="list-style-type: none"> <li>In the voltage code table, the 480V 60Hz code is T6, not Q5. Secondly, the ★ footnote symbol added to voltage codes M5 and T7 because this voltage codes are not available for LC1D40 - LC1D150 contactors. Thirdly, the star footnote mistakenly read, "Not available for LC1D40-LC1D150". Changed to "Not available for LC1D40-LC1D150".</li> <li>The ★ footnote symbol by voltage code is M5 (220V 50 Hz) added.</li> </ul>	3/2004
 <p>Page 16-2 IEC Contactors</p>	<ul style="list-style-type: none"> <li>The picture of the LC1D115 contactor is of a pre-TeSys contactor. Changed to reflect the new TeSys design.</li> <li>The 4-Pole contactors table (second table) has omitted the LP1D40004 and LP1D40008 contactors. Add the LP1D catalog numbers to the table as we have for the D65 and D80 contactors.</li> </ul>	3/2004
 <p>Page 16-2 TeSys D-Line Contactors</p>	<ul style="list-style-type: none"> <li>"... on LC.D09-D32 and LC.DT20-DT40 contactors only..." added to the second sentence in the black, square footnote. New sentence reads "For ring terminal configuration on LC.D09-D32 and LC.DT20-DT40 contactors only, add...."</li> <li>In the top table ..... the 200v max horsepower rating for the LC1D80 should be 25hp not 30hp as shown.</li> <li>The LC1D18 incorrectly listed the Resistive AC1 Ampere rating as 35 amps. Corrected to 32 amps.</li> </ul>	<ul style="list-style-type: none"> <li>3/2004</li> <li>7/2004</li> <li>3/2004</li> </ul>
 <p>Page 16-4 IEC Reversing Contactors</p>	<ul style="list-style-type: none"> <li>The picture on this page is mislabeled. Changed LC2D0901G6 to LC2D09.</li> <li>Changed ■ footnote to read: "For LC2D09 - LC2D32 Electrical interlock can be included by adding a "V" to the end of the catalog number (ex: LC2DO9B7V). List price adder: \$5.00."</li> </ul>	<ul style="list-style-type: none"> <li>3/2004</li> <li>9/2005</li> </ul>
 <p>Page 16-5 TeSys F-Line Reversing</p>	<p>Under the example at the top of the page the auxiliary contacts should read LADN11, since we are slowly phasing out the LA1DN11 and no longer showing it in the digest.</p>	7/2004
 <p>Page 16-6 TeSys Auxiliary Contacts</p>	<p>Two footnote errors corrected in first table:</p> <ul style="list-style-type: none"> <li>The ★ footnote for the first table reads,"1 block only can be mounted on the LC1/LP1 D25 and D32; 2 blocks can be mounted on the LC1/LP1 D40 to D80." This is incorrect. Changed to read, "A maximum of 2 blocks can be mounted on the LC1/LP1 D40 to D80."</li> <li>The ▼ footnote reads "1 block may be added to each side of D-Line contactors." Changed this to read "1 block may be added to the left side of the LC1D 09 to D32, AC Coils only; 1 block may be added to each side of the LC1D 40 to D80 contactors, AC coils only. Cannot be installed on D-Line contactors with DC coils."</li> <li>Reference in the table on the left column beside the LADN10 and LADN01 from LC*D25 to LC*D150 changed to read LC*D40 to D80</li> </ul>	<ul style="list-style-type: none"> <li>3/2004</li> <li>6/2004</li> </ul>
 <p>Page 16-6 TeSys Accessories</p>	<p>For all tables except the Mechanical Latch block, "LP.D40 to D80" and "LC.DT20 to DT40 (4P)" added to each table in the columns headed Snap-On Mounting.</p>	3/2004









[Back to top](#)

[Back to top](#)

Section 16 - IEC Contactors & Starters (cont.)		Change Date
 <p><a href="#">Page 16-7</a> <a href="#">TeSys Accessories</a></p>	<ul style="list-style-type: none"> <li>▪ In the first table for the LAD4R** suppressors, "LC1DT20 to DT40 (4P)" added under the Mounting on column. In the second table for the LA4DE2* and LA4DE3* suppressors, mark the LA4DE2* voltages as AC and mark the LA4DE3* voltages as DC. Additionally delete the words "of wire" in the column headed Installed by: for the LA4DE3*.</li> <li>▪ There is a resistor/capacitor suppressor missing from the first table. Added an LAD4RCG rated 50-127V to the top LC1D09 to LC1D32 (3P) group.</li> <li>▪ The varistor (second) table clarified. The first set of catalog numbers beginning with LAD designated as for use with TeSys contactors. The column headed 'Mounting On' reads:                         <ul style="list-style-type: none"> <li>▪ "LC.D09 to D32"</li> <li>▪ Change this to read:</li> <li>▪ "LC.D09 to D32 TeSys Contactors"</li> <li>▪ The second set of catalog numbers beginning with LA4D designated as for use with pre-TeSys contactors. The column headed 'Mounting On' reads:                                 <ul style="list-style-type: none"> <li>▪ "LC.D09 to D32"</li> <li>▪ change this to read:</li> <li>▪ "LC.D09 to D32 pre-TeSys Contactors"</li> </ul> </li> </ul> </li> <li>▪ In the bottom table, "Cabling Accessories", under the column headed "Mounting on", added "AC Only" to this description.</li> </ul>	<p>3/2004</p>
 <p><a href="#">Page 16-7</a> <a href="#">IEC Coil Suppressors</a></p>	<p>In the first table, the LAD4RCU shows an operating voltage of 110 - 120V. This is incorrect. Changed to 110 - 240V.</p>	<p>3/2004</p>
 <p><a href="#">Page 16-7</a> <a href="#">Accessories</a></p>	<p>The Varistor (second) table needs clarification. The first set of catalog numbers beginning with LAD need to be designated as for use with TeSys contactors. The column headed 'Mounting On' reads: "LC.D09 to D32". Change this to read: "LC.D09 to D32 TeSys Contactors". The second set of catalog numbers beginning with LA4D need to be designated as for use with pre-TeSys contactors. The column headed 'Mounting On' reads: "LC.D09 to D32". Change this to read: "LC.D09 to D32 pre-TeSys Contactors".</p>	<p>3/2004</p>
 <p><a href="#">Page 16-8</a> <a href="#">TeSys D-Line Contactor Accessories</a></p>	<ul style="list-style-type: none"> <li>▪ The Electronic Serial Timer Modules table at the top of the page indicates these accessories can be used with the LP1D09-D32 contactors for 24-250V AC or DC. Add a footnote to specify these contactors are the Pre-TeSys style contactors.</li> <li>▪ Selection table, Electronic Serial Timer Modules list (3) part number for "OFF-DELAY" (LA4DR0U, LA4DR2U, LA4DR4U). These modules are obsolete and not longer available.</li> </ul>	<p>3/2004</p>
 <p><a href="#">Page 16-9</a> <a href="#">TeSys Accessories</a></p>	<ul style="list-style-type: none"> <li>▪ In the first section of this page, added LC1DT20, LC1DT25, LC1DT32, and LC1DT40 to the list of contactors. Then added "LADT9R1", "LADT9R1V", "Not Available", and "Included with Kit" straight across the next line under the Mechanical Interlock and Power Connections portion.</li> <li>▪ In the second section of this page, changed LC1D65 to "LC1D/LP1D65".</li> <li>▪ In the third section of this page, the first line for LC1D80 changed to "LC1D80 AC". Then added "LA9D50978", "LA9D4002" under the Mechanical Interlock and Power Connections portion, on the same line as and before the LA9D8069 and LA9D8070. Added "LC1D80 DC" directly under that line and add "LA9D80978", "LA9D8002", "LA9D8069", AND "LA9D8070" across the line.</li> <li>▪ In the fourth section of this page, deleted the entire first line. Added LC1D115 to the information for the LC1D150 and added "(4P)" to the LA9D11570 catalog number to clarify this is the 4P kit.</li> </ul>	<p>3/2004</p>









[Back to top](#)

[Back to top](#)

Section 16 - IEC Contactors & Starters (cont.)		Change Date
 <b>Page 16-10</b> <b>Accessories</b>	<p>The first table contains a catalog number LA9P3 as a 3-pole (wye-delta shorting strap) for an LC1D09-D32. This is incorrect. Changed this to an LAD9P3.</p>	3/2004
 <b>Page 16-15</b> <b>D-Line AC Coils</b>	<p>The first table on the left titled "For LC1D09-D32 (TeSys) Contactors" retitled to include the LC1DT20-DT40 contactors. It should read, "For LC1D09-D32, LC1DT20-DT40 (TeSys) Contactors, and CAD Relays".</p>	3/2004
 <b>Page 16-15</b> <b>Enclosed Combination Starters</b>	<p>In the top, left table for LC1D09-D32 TeSys Contactors, the 60V coil should be LXD1EE7, not LXD1LE7. And the 208V coil should be LXD1LE7, not LXD1LL7.</p>	3/2004
 <b>Page 16-15</b> <b>Repair Parts</b>	<p>The bottom replacement coil selection table for the LC1D25, D32 contactors should include the following note: "For old style contactors where the catalog number includes the auxiliary contact arrangement (ex: LC1D2510F7)".</p>	3/2004
 <b>Page 16-16</b> <b>F-Line Repair parts</b>	<p>The ◆ footnote at the bottom of the F-line replacement coil table that reads: "Also requires rectifier DR5TE4U, \$72.00 list price." Changed to read: "Also requires rectifier DR5TE4U for 110V - 240V coils, DR5TE4S for 380V - 440V coils. See table below for pricing."</p>	3/2004
 <b>Page 16-16</b> <b>Repair Parts</b>	<ul style="list-style-type: none"> <li>▪ Top left table titled " LC1D40, D50, D65, D80" needs to have the following note added for clarification purposes: "For old style and new TeSys style contactors where the catalog number may or may not include the auxiliary contact arrangement. (ex: LC1D4010F7 or LC1D40F7)" / Top right table titled "LC1D115, D150" needs to have the following note added for clarification purposes; "For old style and new TeSys style contactors where the catalog number may or may not include the auxiliary contact arrangement; (ex: LC1D11500F7 or LC1D115F7)"</li> <li>▪ Top right table titled " LP1D40, D50, D65" needs to have the following additions for clarification purposes: "For LP1D40, D50, D65 and LC1D40, D50, D65" "For old style and new TeSys style contactors where the catalog number may or may not include the auxiliary contact arrangement. (ex. LP1D4011BD or LC1D40BD)". Lower right table titled " LP1D80" needs to have the following additions for clarification purposes: "For LP1D80 and LC1D80" "For old style and new TeSys style contactors where the catalog number may or may not include the auxiliary contact arrangement (ex. LP1D8011BD or LC1D80BD)".</li> </ul>	3/2004
 <b>Page 16-19</b> <b>TeSys Overload Relays</b>	<ul style="list-style-type: none"> <li>▪ The second table, Mounting Kits and Plates, on this page clarified (the column headed <i>For use with overload relays:</i>).</li> <li>▪ A ▲ footnote added for all the "mounting plates" (DX1AP25, DX1AP36, &amp; LA7D902) as follows: "When using mounting plates, separate mounting kits are also required."</li> </ul>	6/2004
 <b>Page 16-19</b> <b>Accessories</b>	<p>The photo is correctly captioned but the "Stop button locking device " is incorrectly listed as a LA7D01 instead of a LA7D901</p>	3/2004










[Back to top](#)

[Back to top](#)

Section 16 - IEC Contactors & Starters (cont.)		Change Date
 <b>Page 16-22</b> <b>TeSys Overload Relays</b>	<p>Overload relay in the upper left corner of the page is erroneously identified as LR9D5.69. Changed to LR9F5.71.</p>	6/2004
 <b>Page 16-24</b> <b>TeSys Dimensions</b>	<p>There are several small errors on this page.</p> <ol style="list-style-type: none"> <li>Table at top left shows qty. 2 dimension "b1". The first b1 should be changed to b and change "add-on blocks" to "top-mounted accessories".</li> <li>Table at top right: title of table shows LC1DT20 to DT60 (4-pole). Change it to LC1DT20 to DT40 (4-pole). <ul style="list-style-type: none"> <li>Change column headed "D253 and DD323" to "D253 and D323".</li> <li>Change column headed "DT32 to DT60" to "DT32 to DT40".</li> <li>Change column headed "DT323 to DT603" to "DT323 to DT403".</li> </ul> </li> <li>Under the LC1D40 etc. sketch the depth dimension of 6.50" (at the bottom ) lists (LA2,LA3,LA6 DK2 ) and it should read (LA2, LA3, LA6 DK1 )</li> </ol>	6/2004
 <b>Page 16-25</b> <b>Approximate Dimensions</b> <b>TeSys D-Line</b>	<ul style="list-style-type: none"> <li>In the first row, the table on the right corrected with TeSys catalog numbers.</li> <li>In the second row, the 6.85" dimension had Di2 and Di3 in parentheses. Revised to LA4D.2.</li> <li>The table to the right corrected with TeSys catalog numbers.</li> </ul>	4/2004
 <b>Page 16-26</b> <b>TeSys Dimensions</b>	<p>Table at top right has an error. Column headed "D25 to DD38" should be changed to "D25 to D38".</p>	6/2004
 <b>Page 16-27</b> <b>TeSys Reversing Contactors</b>	<p>Dimensional drawing at top right side of page: dimension B for contactors D80 and D95 is converted to inches incorrectly. Change 11.0 to 5.0 (same as line directly above it).</p>	6/2004
 <b>Page 16-33</b> <b>Enclosed TeSys Starters</b>	<ul style="list-style-type: none"> <li>Price of catalog number LE1D093A6 (1)(2)(3)(4)(5)(6) changed from \$155.00 to \$109.00.</li> <li>Corrected some horsepower ratings.</li> <li>DC (24v only) is now available on the IEC enclosed starters.</li> <li>Changes to the Overload Table.</li> </ul>	<ul style="list-style-type: none"> <li>3/2004</li> <li>3/2004</li> <li>10/2004</li> <li>10/2004</li> </ul>
 <b>Pages 16-33 &amp; 16-34</b> <b>Enclosed Combination Starters</b>	<ul style="list-style-type: none"> <li>Type 12/3R tables revised.</li> <li>Note under second table deleted: Note: Control Power Transformers are not available when using DC. Also, modified Contactor Coil Voltage Table deleting DC row, and deleting voltages 48, 110, 125, 220, 250, and 440, also under this same table delete 5 = 50 Hz.</li> </ul>	3/2004
 <b>Pages 16-33, 16-34, &amp; 16-36</b> <b>Enclosed Starters</b>	<ul style="list-style-type: none"> <li>Changes made to pages 33 and 34 concerning how we list the auxiliary contacts in the reversing set of contactors.</li> <li>Page 36 has a correction to the top, right drawing labeling.</li> </ul>	3/2004









[Back to top](#)

[Back to top](#)

Section 16 - IEC Contactors & Starters (cont.)		Change Date
 Page 16-34 Enclosed TeSys Starters	<ul style="list-style-type: none"> <li>Corrected some horsepower ratings.</li> </ul>	6/2004
 Page 16-35 Enclosed Combination Starters	<ul style="list-style-type: none"> <li>Connection from terminal 14 to 96 deleted</li> <li>The Start/Stop Push Button w/Green-Red Pilot light is shown as factory modification A06G. This is incorrect. (A06G appears at the top of the selection table as a Start/Stop Push Button). The correct code is A06V.</li> <li>Deleted Forward-Reverse-Stop drawing at lower left of page</li> </ul>	3/2004
 Page 16-35 Enclosed Combination Starters	New InstaKit added to table	3/2004
 Page 16-35 IEC Instakit	Price corrected to \$97.00	3/2004
 Page 16-36 Enclosed TeSys Starters	The non-combination starter dimensions table at the bottom of the page corrected. In the "Non-reversing" column, changed D09-D25 to <b>D09-32</b> ; changed D32-50 to <b>D40-65</b> ; changed D65-80 to <b>D80</b> .	3/2004
 Page 16-38 TeSys K-Line Contactors	The Low Consumption table at the bottom of the page has the last two sets of numbers transposed. The contactors with slip-on connections are supposed to end in 7 while the ones with solder pin connections are supposed to end in 5. The LP5K12105, LP5K12015, LP5K12107, & LP5K12017 are in the wrong place.	6/2004
 Page 16-39 TeSys K-Line	<ul style="list-style-type: none"> <li>Removed the word "Reversing" from the page title. The 4-pole contactors are not considered reversing and this page listed standard 4-pole contactors as well as mechanically interlocked contactors.</li> <li>The picture of the LC2K mechanically interlocked contactor is beside the non-interlocked 4-pole contactor table; this creates confusion. Move it down to be beside the second table listing the mechanically interlocked contactors.</li> </ul>	3/2004
 Page 16-40 TeSys D-Line Contactor Accessories	The LA4KE1UG suppressor module has a voltage range of 130 - 250 Vac and dc, not 201 to 250.	3/2004
 Page 16-43 U-Line Starters	<ul style="list-style-type: none"> <li>In the "Configuring a U-Line Motor Starter" area, changed the 1 thru 5 to read Step 1 thru Step 5.</li> <li>Changed call outs on picture to read Step 1, Step 2, etc.</li> </ul>	6/2004







[Back to top](#)

[Back to top](#)

Section 16 - IEC Contactors & Starters (cont.)		Change Date
 Page 16-44 TeSys U-Line Motor Starters	<ul style="list-style-type: none"> <li>▪ Added a "Step 1." to the left of the <b>Power Bases</b> header for customer convenience to understand the 5 part building block concept .</li> <li>▪ Added the following comment beside the term Power Bases: " - Refer to page 16-43 for all 5 steps.") Also in the ▲ footnote at the bottom correct (LU9M32. ...) to read (LU6MB0. ....)</li> <li>▪ Delete the second and fourth tables from this page ("...For Use in High Density PLC Cards..." - these products will not be developed.</li> <li>▪ LUS130 is an invalid number. Changed to LUS120.</li> </ul>	7/2004
 Page 16-45 TeSys U-Line	<ul style="list-style-type: none"> <li>▪ Add a "Step 2." to the left of the <b>Control Units</b> header for customer convenience to understand the 5 part building block concept .</li> <li>▪ Added the following comment beside the term Power Bases: " - Refer to page 16-43 for all 5 steps."</li> </ul>	6/2004
 Page 16-46 TeSys U-Line	<ul style="list-style-type: none"> <li>▪ Added a "Step 3." to the left of the <b>Function Modules</b> header for customer convenience to understand the 5 part building block concept</li> <li>▪ Added the following comment beside the term Power Bases: " - Refer to page 16-43 for all 5 steps.")</li> <li>▪ Added a "Step 4" to the auxiliary contact function modules on this page.</li> </ul>	6/2004
 Page 16-46 TeSys U-Line Motor Starters	LUFV1 will not be offered, removed from Digest.	6/2004
 Page 16-47 TeSys U-Line	<ul style="list-style-type: none"> <li>▪ Added a "Step 4." to the left of the <b>Auxiliary Contact Blocks</b> header for customer convenience to understand the 5 part building block concept.</li> <li>▪ Added the following comment beside the term Power Bases: " - Refer to page 16-43 for all 5 steps.")</li> <li>▪ LUA1D11 &amp; LUA1D110 products will not be developed, so info deleted from table</li> <li>▪ Deleted part numbers and associated footnote from Auxiliary Contact Blocks table. LUA1C110, LUA1C200 &amp; Solid Diamond Footnote.</li> <li>▪ Deleted part numbers from Additional Accessories table. LU9BD11, LU9BC11 &amp; LU9BC20</li> </ul>	<ul style="list-style-type: none"> <li>▪ 10/2004</li> <li>▪ 10/2004</li> <li>▪ 10/2004</li> <li>▪ 3/2006</li> <li>▪ 3/2006</li> </ul>
 Page 16-48 TeSys U-Line	<ul style="list-style-type: none"> <li>▪ The first catalog number in the first table is wrong. Changed the control circuit contact block catalog number from LUABE20 to LUA8E20.</li> <li>▪ Added a "Step 5." to the left of the <b>Power Base Accessories</b> header for customer convenience to understand the 5 part building block concept.</li> <li>▪ Added the following comment beside the term Power Bases: " - Refer to page 16-43 for all 5 steps.")</li> </ul>	<ul style="list-style-type: none"> <li>▪ 3/2004</li> <li>▪ 6/2004</li> <li>▪ 6/2004</li> </ul>
 Page 16-51 TeSys LS1 Fuseholder	The last catalog number in the first table, LS1DT32 is invalid and its description is wrong. Changed the description to "Screw clamp terminals, 4-pole" to "Auxiliary Main Pole Adder" and changed the catalog number to LA8D324. Additionally, a ▲ footnote added to this new number which reads; "Can be mounted on left-hand or right-hand side of the 3-pole LS1D32 block."	3/2004
 Page 16-51 Fuse Blocks	Fuse data corrected	3/2004









[Back to top](#)

[Back to top](#)

Section 16 - IEC Contactors & Starters (cont.)		Change Date
 <p>Page 16-52 Accessories</p>	<ul style="list-style-type: none"> <li>▪ The middle table titled "Auxiliary Contact Blocks" clarified: Under description column for the first three rows it read: Instantaneous auxiliary contacts; Fault signaling contact + instantaneous auxiliary contact; Short circuit signaling contact. Change to: Instantaneous auxiliary contacts GV2; Fault signaling contact + instantaneous auxiliary contact GV2; Short circuit signaling contact GV2.</li> <li>▪ In the Auxiliary Contact Blocks table, delete the ★ symbol from the Front Mounting Location.</li> <li>▪ Inserted a new symbol and □ footnote stating: "Cannot be used with GV2GH7 insulator".</li> <li>▪ All of the footnotes for this table were incorrect and have been updated.</li> <li>▪ In the second table down the GVAE1 and GVAE20 are sold in lots of 1 not 10 as stated</li> <li>▪ Voltage Trips Chart – Rework description and characteristics columns</li> </ul>	<ul style="list-style-type: none"> <li>▪ 3/2004</li> <li>▪ 6/2004</li> <li>▪ 6/2004</li> <li>▪ 6/2004</li> <li>▪ 6/2005</li> <li>▪ 6/2006</li> </ul>
  <p>Page 16-53 GV2 Starter Accessories</p>	<ul style="list-style-type: none"> <li>▪ Added a ▲ footnote symbol and footnote that reads, "Cannot be used with front-mounted auxiliary contact block".</li> <li>▪ List price on GV2GH7 changed to 10.00 (from 10.40)</li> <li>▪ In the 2nd table down for feeding 3 GV2starters , the following additional selection added: 45 (mm pitch ) / GV2G345</li> </ul>	<ul style="list-style-type: none"> <li>▪ 6/2004</li> <li>▪ 6/2004</li> <li>▪ 3/2005</li> </ul>
 <p>Page 16-56 TeSys GV7</p>	<p>In the last table, Wiring Accessories, we list the Phase Barrier as a GV7AC06. The correct number is a GV7AC04. (The GV7AC06 is the LC1F115-F185 busbar and cover, two lines down.)</p>	<p>3/2004</p>
 <p>Page 16-59 TeSys Wiring Components</p>	<p>In the second table, Power Connection Components for One Starter, the LAD35 has been changed to LAD351.</p>	<p>3/2004</p>
 <p>Page 16-60 Accessories, AK5 Panel Busbar System</p>	<p>Note under the bottom (busbar) table deleted, as catalog is obsolete: "For spacings on other devices see Catalog <a href="#">2520CT9501R6/97</a>. " Reference to Catalog #<a href="#">8502CT0101</a> for additional information is still valid.</p>	<p>8/2004</p>



[Back to top](#)

[Back to top](#)

Section 17 - Push Button & Operator Interface		Change Date
 <b>Pages 17-2 thru 17-119</b> <b>Push Buttons</b>	<p>Catalog section 9001CT0301 is referenced on most pages in section 17. This catalog has not been released yet -- 9001CT0001 is the current version.</p>	<p>9/2003</p>
 <b>Page 17-3</b> <b>Push Button XB4 - XB5 22mm</b>	<ul style="list-style-type: none"> <li>▪ BLACK - Start Push Button should read, BLACK - Start Push Button (flush head)</li> <li>▪ RED - Stop Push Button should read, RED - Stop Push Button (extended head)</li> <li>▪ UR Logo removed and CE Marking referenced</li> </ul>	<p>8/2004</p>
 <b>Page 17-15</b> <b>XB4 22mm</b>	<p><b>Maximum Contact Block usage</b></p> <ul style="list-style-type: none"> <li>▪ first line of table - Push Buttons and Selectors (non-Illuminated) remove words <i>and selectors</i>. Insert line in table. Selector switches (non-Illuminated) 6 blocks</li> </ul> <p><b>Specific Characteristics of Protected LED Light Module Only.</b></p> <ul style="list-style-type: none"> <li>▪ 24V: 19.2 to 30 vdc, 21.6 to <b>26.4 Vac</b> instead of 24.6 Vac</li> </ul>	<p>8/2004</p>
 <b>Page 17-32</b> <b>Push Button XB4 22mm</b>	<ul style="list-style-type: none"> <li>▪ New ■ footnote added after "Plastic guards" in the Description column, "For additional information, reference publication 0106HO9802R8/03."</li> <li>▪ Lamp caption to drawing in left margin -- Lamp part number should be DL1CE*</li> </ul>	<ul style="list-style-type: none"> <li>▪ 3/2004</li> <li>▪ 8/2004</li> </ul>
 <b>Page 17-34</b> <b>XB5 22mm</b>	<p><b>Maximum Contact Block usage</b></p> <ul style="list-style-type: none"> <li>▪ First line of table - Push Buttons and Selectors (non-Illuminated) remove words <i>and selectors</i>. Insert line in table. Selector switches (non-Illuminated) 6 blocks</li> </ul> <p><b>Specific Characteristics of Protected LED Light Module Only.</b></p> <ul style="list-style-type: none"> <li>▪ 24V: 19.2 to 30 Vdc, 21.6 to <b>26.4 Vac</b> instead of 24.6 Vac</li> </ul>	<p>8/2004</p>
 <b>Page 17-35</b> <b>Push Button XB5 22mm</b>	<p>Flush operators with 1 N.O. and 1 N.C. incorrectly listed as XB5AA** = (XB5AZ105 + XB5AA*) change to:</p> <ul style="list-style-type: none"> <li>▪ (ZB5AZ105 + ZB5AA*)</li> <li>▪ XB5AL45 should be ZB5AZ105 + ZB5AL4</li> </ul>	<p>3/2004</p>
 <b>Page 17-37</b> <b>Push Buttons - XB5 22mm</b>	<ul style="list-style-type: none"> <li>▪ Part number XB5AW14A5 is incorrect. Changed to XB5AW14B5.</li> <li>▪ Part number XB5AW35B5 is incorrect. Changed to XB5AW34B5</li> </ul>	<ul style="list-style-type: none"> <li>▪ 3/2004</li> <li>▪ 6/2005</li> </ul>
 <b>Page 17-50</b> <b>Push Buttons - XB5</b> <b>Legend Plates</b>	<p>For clarification, changed the 3rd description down to read: "Custom legend <i>plate and insert</i> (specify .....)"</p>	<p>12/2005</p>







[Back to top](#)

[Back to top](#)

Section 17 - Push Button & Operator Interface (cont.)		Change Date
 Page 17-51 XB5 22mm Legend Plates	<p><b>Last 4 part numbers are wrong</b></p> <ul style="list-style-type: none"> <li>▪ ZBY5002 should be ZBY05002</li> <li>▪ ZBY5004 should be ZBY05004</li> <li>▪ ZBY5001 should be ZBY05001</li> <li>▪ ZBY5005 should be ZBY05005</li> </ul>	8/2004
 Page 17-53 Push Buttons XB5 22mm accessories	ZB5AZ901 -- in the application section for the tool, changed the word "screw" to "mounting nut"	8/2004
 Page 17-55 9001 KA Contact Blocks	The 9001KA contact block family has an error in the ratings we claim on page 17-55. Here it states our contacts are A600-P600. This is wrong, they are A600-Q600.	8/2004
 Page 17-56 Push Buttons - Class 9001 Type K- 30mm	The ◆ footnote symbol removed from the color column to the left of these devices; KR4RHk, KR24RHk, KR5RHk, KR25RHk.	3/2004
 Page 17-57 Push Buttons - Class 9001 Type K- 30mm	In the half filled circle footnote line, the RO (letter) 5 has been changed to R0 (number zero) 5.	3/2004
 Pages 17-59, 17-61, 17- 63 9001K keyed selector switches key options	The ★ footnote text amended as follows: "Additional keys are available at no extra cost." Changed to read " <b>Other key changes</b> are available at no extra cost."	3/2004
 Pages 17-61 Non-Illuminated 3 Position Selector Switch Operators	The ◆ footnote under Spring Return Both..../Key Operated removed, since it is not applicable. These selector switches have a "K5" code as standard as part of the catalog number.	10/2004
 Page 17-65 Pilot Lights	9001 KP44R/G/Y is obsolete	9/2005
 Page 17-82 Push Buttons - Class 9001 Type K and SK - 30mm	Drawing referred to is D30052-287 shown in the left column. Sketch of the legend orientation showing position 1 and 2 added.	3/2004
 Page 17-66 Selector Push Button	Note added above Right and FD columns for the KQ18 that this device is "Maintained". A ★ footnote stating: maintained in right position only added. Function in the right position is similar to a turn to release action.	3/2004



[Back to top](#)

[Back to top](#)







Section 17 - Push Button & Operator Interface (cont.)		Change Date
 <p>Page 17-93 Legend Plate table for push buttons or pilot lights</p>	Entire table realigned for clarity.	8/2004
 <p>Page 17-109 Audible sounder units Illuminated Lens Units with Steady light</p>	<ul style="list-style-type: none"> <li>▪ Deleted the horizontal line in the description column, between the line "90dB at 1m" and "Adjustable from 75-90 dB". Both devices are adjustable.</li> <li>▪ <b>AC/DC</b> added to the Light Source and Voltage column</li> </ul>	3/2004
 <p>Page 17-111 Accessories DL1BEBS</p>	The lamp is 4 Watts for 24 Vac/dc, 5 Watts for the other listed voltages.	3/2004
 <p>Pages 17-111 &amp; 17-112 Push Buttons and Operator Interface</p>	Miniature Beacons and Rotating Lights - Delete second line of header "XVB Illuminated Beacons and Indicating Banks"	6/2006
 <p>Page 17-115 Push Buttons - Class 9001 Type BW</p>	Contact symbol 100 changed to reflect that it has one NO contact per push button with 4 terminals on each.	3/2004
 <p>Page 17-119 Push Buttons-Class 9001 Type SKYP Pendant Stations</p>	Contact symbol 7 modified to show mechanical interlock to be consistent with the product description. The contact did not show the interlocking mechanically like contact block symbol # 10 at the bottom of the page symbol 7 should show that teeter-totter off to the left with the dotted line connection between both button symbols.	3/2004

[Back to top](#)

[Back to top](#)

Section 19 - Limit Switches		Change Date
 Page 19-2 Limit Switches	Added missing information to the Maximum Current Ratings for Control Circuit Contacts chart.	3/2006
 Page 19-19 Osiswitch Limit Switches	Very bottom left corner of page, under interchangeable cable gland -- Plastic and metal switched.	3/2004

[Back to top](#)

Section 20 - Pressure, Vacuum, Temperature and Float Switches		Change Date
 Page 20-1 Section 20 Table of Contents	Following products obsolete, removed from table of contents: <ul style="list-style-type: none"> <li>▪ Level Sensor—9034LSVFW</li> <li>▪ Temperature Switches—9025G</li> <li>▪ Industrial—Electro-Mechanical Float Switches                             <ul style="list-style-type: none"> <li>▪ 9034LLH and LLV</li> <li>▪ 9035D</li> </ul> </li> </ul>	10/2005
 Page 20-10 Replacement Parts Kits Class 9998-For 9012-9038	Following part numbers are obsolete: PC217 through PC232	10/2005
 Page 20-12 Switches Class 9049-Accessories, All Types	Following Types are obsolete: A7A, BF2, C2, C2S, DCA1, DCA2, DCA3, DCA4, DRA31, DRA32, GBR3, GBR5, GBR7, GBR9, GBR11, GBR13, GBR99, GSR3, GSR5, GSR7, GSR9, GSR11, GSR13, GSR99, T2, & T2S,	10/2005
 Page 20-15 Commercial Pressure Switches	In the Special Features and Modifications for Type G Devices table at the bottom of the page, the following comment was inserted after <i>Reverse Action</i> : "select pressure code from rev action table on p. 20-14"	6/2004
 Page 20-16 Vacuum Switches	Vacuum code table moved for clarity.	3/2004
 Page 20-17 Temperature Switches Class 9025-Types GXW and GYW	Page marked obsolete	10/2005















[Back to top](#)

[Back to top](#)

Section 20 - Pressure, Vacuum, Temperature and Float Switches (cont.)		Change Date
 <p>Page 20-18 Type LSV, LSD-Solid State Liquid Level-Class 9034</p>	Page marked obsolete	10/2005
 <p>Page 20-19 Liquid Level Switches Class 9034-Electro Magnetic Float Switches</p>	Page marked obsolete	10/2005
 <p>Page 20-20 Level Sensors Types DG, DW, DR-Open Tank or Sump-Class 9035</p>	Page marked obsolete	10/2005
 <p>Page 20-22 Float Switches Class 9037 Type D Closed Tank</p>	Type D switches obsolete	10/2005
 <p>Page 20-23 Float Switches Types G Closed Tank-Class 9037</p>	Type G switches obsolete	10/2005
 <p>Page 20-24 Float Switches Class 9038- Types B Mechanical Alternators</p>	Type B switches obsolete	10/2005
 <p>Page 20-25 Float Switches Type J Closed Tank-Class 9038</p>	Type J switches obsolete	10/2005
 <p>Page 20-26 Electrical Ratings Class 9012, 9013, 9016, 9025, 9035, 9036, 9037, and 9038</p>	In the table on the bottom left , second row down , second line, changed the "53" to "52"	12/2005


[Back to top](#)

[Back to top](#)









Section 21 - Relays & Timers		Change Date
 Page 21-5 NEMA Control Relays	AC Contact ratings - Add "for DC ratings, see pg. 21-6".	8/2004
 Page 21-6 NEMA Control Relays	DC Contact ratings - Add "for AC ratings, see pg. 21-5".	8/2004
 Page 21-8 TeSys relays	Added to the "Common Voltage Codes" area: "For replacement AC coils, see pg. 16-15 'For LC1D09-D32 TeSys Contactors' table" DC coils are not replaceable.	8/2004
 Page 21-12 IEC Control Relays CA2K	Under Approximate dimensions on the left side, the 3rd header down, 2nd line changed to read (see page 22-16..... ) not 22-15	3/2004
 Page 21-18 Miniature plug-in relays	The contact rating table (on the HTML version) was incorrect. It implied that contact ratings are for a particular device only. The printed and PDF pages are OK.	1/2005
 Page 21-19 Relay Sockets	CSA File number should be <b>211268</b> and NOT LR84913.	3/2004
 Page 21-19 Relay Sockets Accessories	Hold Down Strap Change -- new product 8501NH7	7/2004
  Page 21-22 General Purpose Plug-In Timers	<ul style="list-style-type: none"> <li>▪ In Fixed Time Delay table - The off delay with power trigger type number should be JCK2F(XXXX)PT.</li> <li>▪ 9050JCK Timers -- new product</li> </ul>	7/2004
 Page 21-22 9050JCK timers	CSA File number should be <b>70120</b> and NOT LR60905	3/2004
 Page 21-23 IEC Type Electronic Timers RE7	<ul style="list-style-type: none"> <li>▪ Add the statement "These timers offer multi range timing from .05 to 300 hours, in 10 timing ranges." after the heading "Multi-Function Timers".</li> <li>▪ In the Relay Output Column to the left of the RE7TP13BU, please add a "diamond" symbol behind the 2 C/O.</li> </ul>	3/2004
   Page 21-35 PHASEO DC Power Supply	<ul style="list-style-type: none"> <li>▪ The input voltage for the last product listing on the page changed from "100-240" to read "400-520." Also, the list prices of the last three catalog numbers are incorrect as well. Correct listings; ABL7UPS24100 is \$569. ABL7UPS24200 IS \$725.; ABL7UPS24400 is \$880.</li> <li>▪ ABL7 -- new product , July 2004</li> <li>▪ Discount schedule changed to CP12</li> </ul>	<ul style="list-style-type: none"> <li>▪ 3/2004</li> <li>▪ 7/2004</li> <li>▪ 7/2004</li> </ul>

[Back to top](#)

[Back to top](#)





Section 21 - Relays & Timers (cont.)		Change Date
 Page 21-39 thru 21-48 Relays and Timers	Zelio Plug-in Relays/Zelio Analog Interface Modules/Zelio Count Counters – Addition of 10 new pages to cover the launch of new product.	6/2006

[Back to top](#)


Section 22 - Terminal Blocks		Change Date
 Page 22-10 Two Tier and Grounding blocks	For the Two Tier and Grounding Blocks AB1ETN* and AB1TEN3 and 4, the maximum voltage column listing corrected to read 300 volts, not 600 V.	12/2005
  Page 22-18 Power Distribution Blocks Page 22-19 Fuse Holders Page 22-20 NEMA Type Terminal Blocks	All pricing corrected	3/2004 & 11/2004
 Page 22-19 Fuse Holders, Type FB-Class 9080 600 Volt--Class H Only-- (Copper Only)	Deleted single pole from 100 Amp Rating	3/2004
 Page 22-20 NEMA Type Terminal Blocks Type K-Class 9080	<ul style="list-style-type: none"> <li>• 9080KS1 obsolete</li> <li>• 9080KE1 obsolete</li> </ul>	<ul style="list-style-type: none"> <li>▪ 11/2004</li> <li>▪ 9/2005</li> </ul>
   Page 22-21 Cable Ends	<ul style="list-style-type: none"> <li>▪ Corrected discount Schedule from "CP" to "I"</li> <li>▪ Removed UL from the end of many catalog numbers and modified the ■ footnote. Also removed the bold face from some catalog numbers.</li> </ul>	<ul style="list-style-type: none"> <li>▪ 3/2004</li> <li>▪ 9/2004</li> </ul>
 Page 21-31 Relays & Timers	Changes in voltages column for the Phase Failure Relays and in the Output Relay column. Deletion of the footnote for this chart.	3/2006

[Back to top](#)


[Back to top](#)

Section 24 - AC Drives & Soft Starts		Change Date
   <p><a href="#">Page 24-1 AC Drives &amp; Soft Starts</a></p>	<ul style="list-style-type: none"> <li>▪ Altivar 28 obsolete, replaced by Altivar 31</li> <li>▪ LH4N Mini soft Start obsolete, replaced by Altistart 01 Soft Starts</li> <li>▪ Altivar 71 added</li> <li>▪ S-Flex(tm) Combination bypass package with Altivar 31 for commercial HVAC applications added</li> <li>▪ "Class 8859 58M" corrected to "Enclosed 58M"</li> <li>▪ "Class 8839 Type CPD-18 Pulse" changed to read "PowerGard(tm) 18-Pulse"</li> <li>▪ Added reference "For additional information on the ATV71, reference catalog #8800CT0501_."</li> <li>▪ Photo changes:                             <ul style="list-style-type: none"> <li>▪ Altivar 58 TRX Type N replaced with a S-Flex photo</li> <li>▪ Altivar 58 TRX Type H photo moved to location Type F photo</li> <li>▪ Photo of Altivar 71 replaced photo of 58 TRX Type H</li> </ul> </li> </ul>	<ul style="list-style-type: none"> <li>▪ 11/2004</li> <li>▪ 11/2004</li> <li>▪ 9/2005</li> <li>▪ 9/2005</li> <li>▪ 9/2005</li> <li>▪ 9/2005</li> <li>▪ 9/2005</li> </ul>
 <p><a href="#">Page 24-2 AC Drives and Soft Starts</a></p>	<ul style="list-style-type: none"> <li>▪ For Line Reactors and Motor Protection Output Filters, added "and peripheral equipment"</li> <li>▪ "Product Support Group" changed to "Technical Support"                             <ul style="list-style-type: none"> <li>▪ Mailing address contact added to contact info</li> </ul> </li> <li>▪ For Square D Seneca, SC services, modified to read "Packaged Drives and Soft Starts - mounted in MCCs &amp; Enclosures"</li> <li>▪ "Documentation" changed to "Packaged Product Documentation"                             <ul style="list-style-type: none"> <li>▪ The following sentence deleted: Additional instruction bulletins are available for <b>\$30.00</b> net each.</li> <li>▪ IGS, Microcad added as available drawing types</li> </ul> </li> </ul>	<p>9/2005</p>

[Back to top](#)

Section 25 - Automation Products		Change Date
 <p><a href="#">Page 25-1 thru 4 Automation Products</a></p>	<ul style="list-style-type: none"> <li>▪ Updated of all products listed on these pages, including some new photos, charts and copy.</li> </ul>	<p>6/2006</p>

[Back to top](#)

Product Locator Index - Alphabetical		Change Date
 <p><a href="#">Page i-1 Product Locator Index - Alphabetical</a></p>	<p>Page number change - Air Conditioning Disconnects from page 1-15 to 1-19.</p>	<p>3/2006</p>

[Back to top](#)