

CODE FINDER 2002 NATIONAL ELECTRICAL CODE®

Reg. Trademark of NFPA

Section	
<i>Article 110</i>	<i>Requirements for Electrical Installations</i>
110.3(B)	Installation and Use of Equipment
110.9	Interrupting Rating
110.10	Circuit Impedance and Other Characteristics
110.12(C)	Integrity of Electrical Equipment and Connections
110.14(C)	Temperature Limitations (Terminations and Devices)
110.26	Space about Electrical Equipment
<i>Article 210</i>	<i>Branch Circuits</i>
210.8(A)	GFCI Protection for Personnel (Dwelling Units)
210.8(B)	GFCI Protection for Personnel (Other than Dwelling Units)
210.11	Branch Circuits Required
210.12	Arc-Fault Circuit Interrupter
210.20	Overcurrent Protection
<i>Article 215</i>	<i>Feeders</i>
215.3	Overcurrent Protection for Feeders
215.10	Ground-Fault Protection of Equipment
<i>Article 220</i>	<i>Branch Circuit, Feeder and Service Calculations</i>
220.3	Branch Circuit Load Computations
<i>Article 225</i>	<i>Outside Branch Circuits and Feeders</i>
225.30	Number of Supplies
<i>Article 230</i>	<i>Services</i>
230.40	Number of Service Entrance Conductor Sets
230.71	Maximum Number of Disconnects
230.90(A)	Overcurrent Protection (Ungrounded conductor)
230.95	Ground-Fault Protection of Equipment
<i>Article 240</i>	<i>Overcurrent Protection</i>
240.4	Protection of Conductors
240.6	Standard Ampere Ratings
240.8	Fuses or Breakers in Parallel
240.20(B)	Circuit Breaker as Overcurrent Device
240.21	Location in Circuit
240.83	Markings (Circuit Breakers)
240.86	Series Ratings
<i>Article 250</i>	<i>Grounding</i>
250.24(B)	Grounded Conductor Brought to Service Equipment
250.30	Grounding Separately Derived AC Systems
250.32	Two or More Buildings or Structures Supplied for a Common Service
250.50	Grounding Electrode System
250.122	Size of Equipment Grounding Conductors
<i>Article 280</i>	<i>Surge Arresters</i>
280.4(A)	Listing for Surge Arresters <1000V
<i>Article 285</i>	<i>Transient Voltage Surge Suppressors (TVSS)</i>
285.5	Listing
285.6	Short Circuit Current Rating
285.21	Connection
<i>Article 310</i>	<i>Conductors for General Wiring</i>
310.4	Conductors in Parallel
310.15	Ampacities of Conductors
<i>Article 408</i>	<i>Switchboards and Panelboards</i>
408.14	Classification of Panelboards
408.15	Number of Overcurrent Devices in One Panelboard
408.16(F)	Back-fed Devices
408.21	Grounded Conductor Terminations
<i>Article 430</i>	<i>Motors, Motor Circuits and Controllers</i>
430.6	Ampacity and Motor Rating Determination
430.52	Rating or Setting for Individual Motor Circuits
430.102	Location of Disconnecting Means
430.150	Table-FLC - Three Phase Motors

CODE FINDER 2002 NATIONAL ELECTRICAL CODE®

Reg. Trademark of NFPA

Section	
<i>Article 450</i>	<i>Transformers</i>
450.3	Overcurrent Protection
<i>Article 517</i>	<i>Health Care Facilities</i>
517.17	Ground Fault Protection
<i>Article 525</i>	<i>Carnivals, Circuses, Fairs and Similar Events</i>
525.23	GFCI Protection for Personnel
<i>Article 527</i>	<i>Temporary Installations</i>
527.6	Ground-Fault Protection for Personnel
<i>Article 680</i>	<i>Swimming Pools, Fountains and Similar Installations</i>
680.32	GFCI - Storable Pools
680.41	Emergency Switch for Spas and Hot Tubs
680.44	GFCI - Spas and Hot Tubs
680.51(A)	GFCI - Fountains
680.62(A)	GFCI - Therapeutic Tubs
680.71	GFCI - Hydromassage Bathtubs
<i>Article 695</i>	<i>Fire Pumps</i>
695.3(A)(1)	Electric Utility Service Connection
1999 NEC	2002 NEC
	Article Title
300	300 Wiring Methods
305	527 Temporary Installations
310	310 Conductors for General Wiring
318	392 Cable Trays
320	398 Open Wiring on Insulators
321	396 Messenger Supported Wiring
324	394 Concealed Knob-and-Tube Wiring
325	326 Integrated Gas Spacer Cable: Type IGS
326	328 Medium Voltage Cable: Type MV
328	324 Flat Conductor Cable: Type FCC
330	332 Mineral-Insulated, Metal-Sheathed Cable: Type MI
331	362 Electrical Nonmetallic Tubing: Type ENT
333	320 Armored Cable: Type AC
334	330 Metal-Clad Cable: Type MC
336	334 Nonmetallic-Sheathed Cable: Types: NM, NMC, and NMS
338	338 Service-Entrance Cable: Types SE and USE
339	340 Underground Feeder and Branch-Circuit Cable: Type UF
340	336 Power and Control Tray Cable: Type TC
342	382 Nonmetallic Extensions
343	354 Nonmetallic Underground Conduit with Conductors: Type NUCC
345	342 Intermediate Metal Conduit: Type IMC
346	344 Rigid Metal Conduit: Type RMC
347	352 Rigid Nonmetallic Conduit: Type RNC
348	358 Electrical Metallic Tubing: Type EMT
349	360 Flexible Metallic Tubing: Type FMT
350	348 Flexible Metal Conduit: Type FMC
351 (Part A)	350 Liquidtight Flexible Metal Conduit: Type LFMC
351 (Part B)	356 Liquidtight Flexible Nonmetallic Conduit: Type LFNC
352 (Part C)	384 Strut-Type Channel Raceway
352 (Part A)	386 Surface Metal Raceways
352 (Part B)	388 Surface Nonmetallic Raceways
353	380 Multioutlet Assembly
354	390 Underfloor Raceways
356	374 Cellular Metal Floor Raceways
358	372 Cellular Concrete Floor Raceways
362 (Part A)	376 Metal Wireways
362 (Part B)	378 Nonmetallic Wireways
363	322 Flat Cable Assemblies: Type FC
364	368 Busways
365	370 Cablebus
370	314 Outlet, Device, Pull, and Junction Boxes, Conduit Bodies, Fittings; and Cabinets, Cutout Boxes, and Meter Socket Enclosure
373	312 Cabinets, Cutout Boxes, and Meter Socket Enclosure
374	366 Auxiliary Gutters
380	404 Switches
384	408 Switchboards and Panelboards